



# ASSESSMENT OF MARKET POTENTIAL

## Demo4Grid

---

DELIVERABLE 6.1

GRANT AGREEMENT 736351

STATUS: DRAFT / FINAL DRAFT / **FINAL**

**PUBLIC** / CONFIDENTIAL



*This project has received funding from the Fuel Cells & Hydrogen 2 Joint Undertaking (FCH2 JU) of the European Commission under grand agreement No 736351 and the Swiss State Secretariat for Education, Research and Innovation (SERI) under contract number 17.00002. FCH2 JU receives support from the European Union's Horizon 2020 research and innovation programme and Hydrogen Europe and N.ERGHY.*

The contents of this document are provided “AS IS”. It reflects only the authors’ view and the JU is not responsible for any use that may be made of the information it contains.

George Athanasiou<sup>1</sup>

Guillermo Matute<sup>2</sup>

Ewald Perwoeg<sup>3</sup>

Nikolaus Fleischhacker<sup>4</sup>

<sup>1</sup> Diadikasia Business Consultants S.A. (DIAD). Greece

<sup>2</sup> Instrumentación y Componentes (INYCOM). Spain

<sup>3</sup> MPREIS Warenvertriebs GmbH (MPREIS). Austria

<sup>4</sup> FEN Sustain Systems GmbH (FEN). Austria

## DOCUMENT CHANGE CONTROL

Version Number	Date	Author(s)	Brief Description of changes
V0	28.02.19	Manos Stamatakis	First draft document
V01	02.04.19	George Athanasiou	Second draft document; incorporated data for Greece
V02	15.04.19	Manos Stamatakis	Third draft document; incorporated data for Austria & Spain
V03	20.12.19	Manos Stamatakis	Final document; incorporated comments made by PO

## OBJECTIVES

The overall objective of Deliverable 6.1. Assessment of Market Potential is to pave the way towards commercialization of the Pressurized Alkaline Electrolyzer (PAE), mainly in grid balancing applications, but other markets as well. Specific targets of this Deliverable are: 1) to assess the market potential of PAE as a means to provide grid balancing and supplying hydrogen to different markets and applications at EU level, 2) to identify available national EU policies promoting Renewable Energy Sources and Energy Storage (including Hydrogen), 3) to come up with an overview of the European electricity markets organization and operation and to compare prices of electricity amongst different Member States, 4) to assess potential markets and business climate for hydrogen produced through electrolysis in different applications and markets, and to identify specific end-users, 5) assess the available funding and financing tools and programs and related support policies and develop a list of recommendations on necessary future modifications on them, 6) conduct a sensitivity analysis on existing market opportunities and critical factors affecting the penetration of PAE to the European market, 7) identify the business related risks as well, 8) estimate current and future perspectives of this emerging market and 9) develop the most important conclusions from the overall analysis.

# CONTENTS

Document Change Control .....	3
Objectives .....	4
Contents .....	5
1. Objectives .....	7
2. INTRODUCTION: Why Hydrogen in Grid Balancing .....	7
3. EU policies for the promotion of Renewable Energy Sources and Energy Storage .....	11
3.1. EU policies for the promotion of Renewable Energy Sources .....	11
3.2. EU policies for the promotion of Energy Storage (including hydrogen) .....	29
2.2.1 Austria .....	32
2.2.2 Spain .....	34
2.2.3 Greece .....	36
4. Overview of European Electricity Markets and Prices .....	37
4.1. Overview of Electricity Prices for Industrial Electrolyzers at EU level .....	38
4.2. Identification of Electricity Prices for Industrial Electrolyzers in the targeted EU countries ...	40
3.2.1 Austria .....	40
3.2.2 Greece .....	41
5. Business Climate for Grid Balancing / Current Markets for Pressurized Alkaline Electrolyzers in Europe .....	42
5.1. Power to Gas .....	44
5.2. Power to Mobility .....	46
5.3. Power to Industry .....	47
5.4. Power to Power (Re-electrification of Hydrogen) .....	48
5.5. Grid Services Provision .....	49
5.6. Power to Heat .....	51
5.7. List of at least 10 market opportunities at EU level .....	51
6. Concepts of Financing and Support .....	54
6.1. Austria .....	55
6.2. Spain .....	57
6.3. Greece .....	60

7.	Market Opportunities Analysis / Solid Business Cases Definition .....	60
7.1.	Existing Market Opportunities Analysis / Solid Business Cases Definition .....	61
7.2.	Identification of Critical Factors affecting Market Penetration .....	64
7.3.	Bankability Analysis of Business Cases .....	65
8.	Identification of Risks and De-risking at Business Level / Recommendations to decrease Risks .....	67
8.1.	De-Risking of Power to Hydrogen Applications .....	67
8.2.	Recommendations on Modifications to Regulatory Frameworks to decrease Risks .....	69
9.	Current and Future Cost Perspectives .....	70
9.1.	Current Costs of Alkaline Electrolyzers .....	70
9.2.	Future Cost Perspectives of Alkaline Electrolyzers .....	71
10.	Conclusions.....	73
	References .....	75

## 1. OBJECTIVES

The objective of Deliverable 6.1 is to assess, at EU level, the market potential of PAE providing grid services and supplying hydrogen to multiple hydrogen markets. It will be important to identify in a first stage what countries have a regulation inclined to the promotion of the use of PAE for grid services provision. In parallel, it will be also needed to determine the countries, locations or areas where the hydrogen produced (and incidentally also the oxygen) can be supplied to the end user.

The methodology is focused on the national policies towards renewable energy and energy storage, availability and price of electricity, business climate, the presence of target sectors (e.g. manufacturers) and users, and possible other drivers that could assist in the wider implementation (such as EU structural funds).

## 2. INTRODUCTION: WHY HYDROGEN IN GRID BALANCING

The replacement of fossil fuels with renewable energy sources at EU level will demand a total transformation of its energy system. The new EU energy system will be characterized by two basic modifications: 1) Highly increasing power generation from Renewable Energy Sources and 2) Increased electrification of energy end-use segments. The combination of the above parameters create significant challenges for the electrical stability of the emerging power system, since on the one hand the *power supply* is intermittent (wind and solar power production varies significantly both in the short and long-term), and on the other hand the *power demand* is variable (daily and seasonal), resulting in the fact they do not easily match over long periods of time. These characteristics of the new energy system result in problems related to voltage and frequency of the electrical network and frequent power curtailments, especially from the wind parks.

These problems are even more severe in autonomous – isolated power systems, such as the ones serving the non-interconnected islands. Therefore, measures related to energy storage, to achieve grid balancing should be enforced in the electricity networks at EU level. Such measures will significantly contribute in higher RES penetration and the production of useful energy carriers (electricity and hydrogen) that could be used in a variety of applications. The variable power production of renewables, especially when exceeding specific thresholds, in combination with the daily and seasonal variable power demand, creates a need for short and long – term grid balancing.

The basic concept of grid balancing is related to the introduction of additional load demand, especially in the periods of high renewable energy production and low power demand, which absorb excess renewable energy, which can be sent back to the grid at periods of low production from wind and solar parks.

It is widely known that in order to balance the variations of power production from renewables and power consumption and ensure that stability of the electricity grid, there are different methods and approaches:

1. The simplest balancing method used widely in the past was the enforcement of power curtailments in wind parks mainly at periods of high renewable energy production. According to this method, the operator of the electricity grid provides wind energy producers with low set-points of operation / production, or even shuts-off the entire wind energy production. This method is highly ineffective, since on the one hand it significantly increases the payback period of large investments in the field of renewable energy and on the other hand it significantly reduces renewable energy penetration in the overall energy system. In case of high demand and low renewable energy production, the simplest method used in the past was to turn on additional generators driven by fossil fuels, which is not a good option as well, since this strategy is not compatible with EU decarbonization targets
2. The new and emerging EU energy system uses modern and innovative techniques for grid balancing:
  - 1) The first approach for the new grid balancing method is a combination of coupling different sectors and an interconnection of the building heating and cooling demand, the transport and industrial sector as energy consumers with power generation. Such an approach provides a higher stability to the renewable energy system,
  - 2) The second approach for grid stabilization and balancing is the application of long-term storage / discharge technologies and
  - 3) The third approach is the transportation of energy from centers of supply to centers of demand, using also smart grid techniques. The first approach enables balanced demand between different sectors, the second one provides grid balancing directly through the storage / discharge units of renewable power, while the third approach can be combined with the other ones, in order to come up with a stabilized, efficient and environmentally friendly EU energy system

Hydrogen is an ideal solution for grid balancing, both as a mechanism for coupling of sectors, and as a long – term plus large – scale energy storage option. Hydrogen can also serve ideally the third grid balancing approach as well, since it can be transported from centers of supply to centers of demand. In other words, hydrogen is necessary to ensure the transition to the transformed EU energy system. In more detail, the contribution of hydrogen to grid balancing of the emerging EU system (for each of the three approaches) is being analyzed below:

- **Sector coupling:** The basic concept behind coupling of sectors lies in the direct connection of power generation with other energy demand sectors, such as the one of transport. This approach solves two problems related to grid balancing: a) energy is not produced at the location where it is required and b) it is not produced at the time it is required. The following technologies of the approach are used:
  - *Power to heat:* This is an interesting technology, using the excess of renewable energy production to supply heating / cooling for buildings or other infrastructure, driving electric boilers, heat pumps etc., or feed it directly into the district heating



infrastructure, wherever it is available. The power to heat technique is generally efficient, nevertheless has specific drawbacks: a) it can only be used in specific applications (buildings and infrastructure), b) it does not contribute significantly to grid stabilization, since the timing of excess renewable energy production and heating / cooling demand is usually different and c) Long – term heating storage is not possible without degradation

- *Power to gas*: This is a more flexible sector coupling option in terms of achieving grid balancing and stabilization. Hydrogen can play an important role in this method, since in contradiction with other gases, the conversion of excess power to hydrogen through electrolysis can be a cost-efficient solution, especially when there is abundant renewable power. By using this method of hydrogen production through electrolysis driven by excess renewable energy, the emerging EU system can be stabilized on a yearly basis and high RES penetration accompanied with very low wind energy curtailments can be achieved. Hydrogen is as flexible as Natural Gas and in addition this option produces zero greenhouse gas emissions (especially CO<sub>2</sub>). Moreover, hydrogen has the advantages of rapid scale-up, storage and efficient power distribution to a variety of other energy consuming segments, without introducing a need for major infrastructure modifications as well
- **Storage and discharge**: The option of storage / discharge is complementary to the approach of sector coupling, in order to achieve direct grid balancing and stabilization. Batteries can be considered as an obvious solution for this method of grid balancing, but they have specific disadvantages: a) they can only store energy for short-term periods, b) they are also expensive when taking into account the amount of energy stored and c) they have significantly lower energy density. Therefore, the main drawbacks of this technology are that they cannot store high energy amounts, especially for longer periods of time. With respect to storage and discharge method for grid balancing, there are specific technologies that can be used:
  - *Pumped Hydro*: This is a well appreciated long –term energy storage option, which unfortunately has a limited application in the EU energy system. Another drawback of this technology is the fact that it has specific natural, regulatory, permitting and social related barriers. Pumped hydro units have also another disadvantage: they can only be installed in selected geographical area, having specific characteristics, therefore their application is limited
  - *Hydrogen*: It has the advantages of storing energy in the long – term, at higher quantities (large –scale energy storage) and at a competitive cost as well, when compared to other conventional large – scale energy storage technologies, such as pumped hydro. This storage / discharge option may have a lower conversion efficiency compared to other technologies, it is widely accepted that the re-electrification of hydrogen (and the associated low conversion factors) will not be required, since hydrogen can be used in a variety of applications, such as the transport and industrial sector and also provide heat for buildings and related infrastructure. Another

advantage of hydrogen compared to other storage solutions, such as pumped hydro is the fact that EU has significant H<sub>2</sub> storage capacities. EU has a grid capacity of 36 billion m<sup>3</sup> and if we assume a 10% blending then the energy storage capacity in the form of hydrogen is in the order of 100 TWh (Eurogas (2015): Statistical Report). Specific geological formations, such as salt caverns and depleted gas fields will be used in the future for storing hydrogen. It has been calculated that almost 40 TWh of hydrogen can be stored only in salt caverns in the EU (Gillhaus, A. (2007): Natural Gas Storage in Salt Caverns – Present Status, Developments and Future Trends in Europe). It is also important that the technical feasibility of this concept has already been proved, since six projects related to storing hydrogen in salt caverns are already in operation today

- **Transportation of energy:** This is the third approach for grid balancing, dealing with the fact that except the seasonality of supply, the location of supply is also critical. It is widely known that the renewable energy installations are often situated in areas that cannot absorb the entire production of wind and solar parks. The solution of building energy transmission lines infrastructure has a high cost. Hydrogen provides an advantageous solution for this grid balancing approach as well, since after the conversion of electricity to this energy carrier, it can be transported in liquid and compressed form, or transferred through pipelines

In the following Figure 1.1 (Hydrogen Roadmap Europe: A SUSTAINABLE PATHWAY FOR THE EUROPEAN ENERGY TRANSITION, FCH JU and European Commission, January 2019), a comparison of sector coupling and storage technologies is depicted, clearly showing the advantages of hydrogen in grid balancing applications.

**Figure 1.1.** Comparison of sector coupling and storage technologies for grid balancing (Hydrogen Roadmap Europe: A SUSTAINABLE PATHWAY FOR THE EUROPEAN ENERGY TRANSITION, FCH JU and European Commission, January 2019)

Options for stabilizing RES system		Suitability			Assessment	Suitability for long-term storage?
		Intra-day	Intra-month	Seasonal		
Over-supply	Reduce supply	Shut down RES			<ul style="list-style-type: none"><li>Technically feasible</li><li>Inefficient, losses of investment</li></ul>	✗
	Sector coupling	Power-to-material (P2M)			<ul style="list-style-type: none"><li>No reconversion to power possible</li><li>In R&amp;D stage</li></ul>	✗
		Power-to-gas (P2G)			<ul style="list-style-type: none"><li>Technically feasible in number of use cases</li><li>Currently high investment cost</li></ul>	✓
		Power-to-heat			<ul style="list-style-type: none"><li>Efficient, discharge only to heat (not power) possible</li><li>Suitable for short-term balancing only</li></ul>	
		Power-to-gas-to-power (P2G2P)			<ul style="list-style-type: none"><li>Reconversion possible</li><li>Low full cycle efficiency</li><li>Only if P2G not suitable/sufficient</li></ul>	✓
Under-supply	Store and discharge	Bat-tery	Compressed air, flywheel		<ul style="list-style-type: none"><li>Technically feasible</li><li>Only short-term supply economically viable</li></ul>	✗
			Pumped hydro	Hydro reservoir (Scandinavia; Alps; ...) incl. interconnectors	<ul style="list-style-type: none"><li>Limited storage capacity due to natural limitations</li></ul>	✗
	Reduce demand <sup>1</sup>	Demand side management (DSM)			<ul style="list-style-type: none"><li>Consumption pattern only allows for limited shift within day</li></ul>	✗
	Increase supply	Structural renewables oversupply			<ul style="list-style-type: none"><li>Technically feasible</li><li>Highly inefficient and capital intensive, losses of investment</li></ul>	✗
		Conventional backup (e.g., gas plants)			<ul style="list-style-type: none"><li>Feasible if power generation is decarbonized (e.g., pre-combustion CCS)</li></ul>	

<sup>1</sup> Demand reduction/demand balancing beyond expected structural demand reduction and efficiency gains (e.g., via energy-efficient renovations of buildings)

### 3. EU POLICIES FOR THE PROMOTION OF RENEWABLE ENERGY SOURCES AND ENERGY STORAGE

In the context of this Chapter of Deliverable 6.1, the most significant EU policies for the promotion of Renewable Energy Sources and Energy Storage will be presented. Specific targets for the targeted EU Member States (Spain, Austria and Greece) in these fields will also be demonstrated.

#### 3.1. EU policies for the promotion of Renewable Energy Sources

The promotion of Renewable Energy Sources in the European Union has been adopted through the Directive 2009/28/EC, which set specific goals for the RE share in the European energy mix of at least 20%, by 2020. The above mentioned Directive was revised in 2018. The revised Renewable Energy Directive resulted in a European policy adopting one of the most ambitious policies in the field worldwide. The revised Renewable Energy Directive is part of the **Clean Energy for all Europeans Package**. The main components of this policy are the following:

- The revised Renewable Energy EU Directive continues European leadership in the field, setting a binding target of renewables **of at least 27%, by 2030** in the energy system of Europe
- The Directive significantly contributes to Europe's fight **against climate change** and the achievement of Paris Agreement climate goals
- The new Directive contributes in the protection of EU environment and will specifically help in reducing **air pollution in European cities and regions**
- The Revised Renewable Energy EU Directive gives the chance (and allows) households, communities and companies to **become producers of clean energy** and contribute to the reduction of greenhouse gas emissions
- It also reduces the dependency of the European Union on energy imports and increases **the security of energy supply**
- The revised RE Directive highly contributes in the **creation of more job positions** and in the attraction of **new investments** in the European economy related to energy

The new policy framework established for renewables, incorporated through the adoption of the revised EU Directive results in specific benefits:

- It provides a longer – term risk reduction for investors and speeds up the procedures to receive permits for Renewable Energy projects
- It introduces an innovation, where the energy consumer has an important role in the energy transition, having a clear right to produce its own renewable energy and distribute it to the European electricity grid
- It helps increasing the competition and the integration of renewable electricity to the market
- It will accelerate the uptake of renewable energy sources in other sectors such as heating / cooling and transport applications
- It has a main focusing on increasing the sustainability of bio-energy and promoting innovative technologies (including hydrogen production as a grid-balancing method)

*(Source: The Revised Renewable Energy Directive factsheets – European Commission)*

The policies and measures for the targeted countries (Austria, Greece and Spain) for the promotion of Renewable Energy Sources will be presented in detail in the following sections:

- **Austria:** The 2010 National Renewable Energy Action Plan of the country was developed to adopt the Directive 2009/28/EC. According to this Directive Austria must increase its renewable energy share in the final energy consumption to 34% by 2020. This figure in 2005, which is used as a base year was 24.4%, while in 2008 this value had already reached 29%. The achievement of this target will be based on the following two conditions:
  - In comparison to the reference scenario of base year 2005, a total reduction of final energy consumption in the order of 13% should be achieved
  - The installed capacity of renewable energy should be increased by 18% in comparison to the installed capacity of 2008

The target of 34% renewables in the final energy consumption of Austria can be achieved by different mixes of each renewable energy technology. In addition to renewable energy technologies producing electricity such as wind, solar and hydro, the exhaustion of available biomass potential is almost important to provide heating and cooling in order to achieve the 10% biofuel target. To determine the final energy mix of different renewable energy technologies in order to achieve the above mentioned target, the factors of cost – efficiency, resource availability and environmental protection are taken into account.

With respect to the decrease of final energy consumption in comparison to the reference scenario, required in the context of the national renewable energy plan of Austria, the following reductions should be achieved in the three main areas of energy use:

- 22% reduction in the transport sector
- 12% reduction in heating and cooling, and
- 5% reduction in the electricity sector

The National Renewable Energy Action Plan identifies the existing or planned measures and policies that will be used in order to achieve its targets and promote the use of energy produced from renewable energy sources. The most significant measures and policies in the Austrian plan are presented in the following Tables:



**Table 2.1. Overview of all policies and measures of the National Renewable Energy Action Plan of Austria (National Renewable Energy Action Plan 2010 for Austria (NREAP-AT), under Directive 2009/28/EC of the European Parliament and of the Council**

Name and reference of the measure	Type of measure	Expected result	Targeted group and/or activity	Existing or planned	Start and end dates of the measure
<b>Horizontal measures</b>					
<b>Austrian Energy Strategy – proposals for measures</b>	Overall strategy	Strategic focus on a future energy and climate policy	End consumers, public administration, interest groups, etc.	Existing	Implementation planned, Continuous updating
<b>Austrian climate protection initiative (klima:active)</b>	Information campaign and financial	Promotion and acceleration of the use of renewable energies	End consumers, architects, installers, etc.	Existing	2004 -
<b>Climate and Energy Fund Law (KLI.EN FondsG)</b>	Regulatory	Promotion of renewable energy systems and climate policy	End consumers	Existing	Basic version: 2007 amended 2009
<b>Austria's Environmental Aid Act (UFG)</b>	Regulatory	Promotion of operational measures to protect the environment	End consumers	Existing	Basic version: 1993 amended 2009
<b>Environmental Assistance in Austria (UFI)</b>	Financial	Promotion of renewable energy systems	End consumers	Existing	1993
<b>Law regarding access to information on the environment (UIG)</b>	Regulatory	Free access to information on the environment	The general public	Existing	Basic version: 1993 amended 2009
<b>Agreement pursuant to Article 15a B-VG (Federal Constitutional Law)</b>	Regulatory	Harmonisation and reinforcement of RE measures in the building sector	End consumers	Existing	2009



Name and reference of the measure	Type of measure	Expected result	Targeted group and/or activity	Existing or planned	Start and end dates of the measure
<b>Horizontal measures</b>					
<b>Austrian programme for a sustainable agriculture (ÖPUL)</b>	Regulatory	Compliance with good agro-environmental practices	Farmers	Existing	2007-2013
<b>Climate Change Act</b>	Regulatory	Establishment of binding climate targets and responsibilities	Federal states and affected federal ministries	Planned	
<b>Environmental Tax Reform</b>	Regulatory	Increased taxation of resources and energy consumption	End consumers	In discussion	In discussion
<b>Energy spatial planning</b>	Regulatory	Austrian Conference on Spatial Planning 2011. Integration of targets and measures for energy and climate protection	Federal government, state governments ÖROK	Planned	From 2010
<b>Energy Efficiency Act</b>	Regulatory	Statutory regulations to increase energy efficiency	End consumers, enterprises	Planned	Preparatory work 2010
<b>Buildings</b>					
<b>Technical rules in the building code of state governments</b>	Regulatory	Promotion of renewable energy systems in the building sector	Building permit applicants	Existing, revision planned	Continuous updating
<b>Further development of legal specifications in the building sector</b>	Regulatory	Further development of building and energy-related rules, renovation obligations as well as minimum requirements for the construction and renovation of public buildings	Federal and state government	planned	From 2010
<b>Further development of eligibility criteria</b>	Financial	Stronger focus of housing support on thermal remediation	Federal and state government, End consumers	Planned	Should enter into force in 2013



Name and reference of the measure	Type of measure	Expected result	Targeted group and/or activity	Existing or planned	Start and end dates of the measure
<b>Production, services in industry, business and small-scale consumption</b>					
<b>Certification of installers</b>	Regulatory	Training and awards of technical experts	Installers	Existing, revision planned	2000
<b>Energy efficiency consulting for SME and households, introduction of energy management systems, preparation of energy concepts</b>	Financial information campaign	Support of the implementation of energy efficiency measures and promotion of the use of renewable energy sources	Companies, households, federal and state government	Existing, revision planned	2010/2011
<b>Mobility</b>					
<b>Biofuels Directive</b>	Regulatory	Incorporation of biofuels to fossil fuels	Mineral oil industry	Existing	2004
<b>Law on the taxation of mineral oils (Mineralölsteuergesetz)</b>	Regulatory/financial	Tax relief for biogenic fuels	End consumers	Existing	2007
<b>Five-point action programme for natural and biogas</b>	Information campaign/regulatory	Acceleration of biogas as a fuel	End consumers	Existing	2005 - 2010
<b>Acceleration of a gradual, comprehensive introduction of electromobility in Austria</b>	Strategy (tax incentives, information, awareness-raising, etc.)	Increase in the share of renewable energy in private transport	Companies, federal and state government, local authority, end consumers	In discussion	In discussion
<b>Austrian Action Programme for Mobility Management (klimate:active)</b>	Financial	Promotion of vehicles with low-emission and energy-efficient fleets by companies and local authorities as well as private vehicle owners	Federal and state government, local authority, end consumers	Exists to some extent / extension planned	Phased implementation by 2020





Name and reference of the measure	Type of measure	Expected result	Targeted group and/or activity	Existing or planned	Start and end dates of the measure
<b>Energy supply</b>					
<b>Austrian Gas Act (GWG)</b>	Regulatory	Regulation of the network access for biogas	Producers	Existing	2006
<b>Austria's Heating and Cooling Network Expansion Act (WKLG)</b>	Regulatory	Promotion of renewable energy systems	Producers	Existing	Full doping from 2011
<b>Green Electricity Act (ÖSG)</b>	Regulatory	Promotion of green electricity.	Producers	Existing, revision planned	2002 amended several times
<b>Biogas and biomethane strategy for the chain from application to marketing</b>	Strategy	Use of biomethane in all applications segments through the creation of instruments on the demand side	Federal and state government, local authority, energy suppliers, agriculture, end consumers	Planned	Drafting by 2011
<b>Mobilisation of biomass and use of local and district heating networks (incl. microgrids)</b>	Strategy	Better and sustainable use of potential	Agriculture, forestry and energy producers	Existing, revision planned	Ongoing from 2010
<b>Security of energy supply</b>					
<b>Development of the Austrian transmission and distribution network</b>	Strategy (Masterplan 2009-2020)	Medium and long-term creation of a demand-orientated network infrastructure	Federal government, state system operators	Existing/planned	Ongoing from 2010
<b>District heating and cooling</b>	Financial	Infrastructure extension and reinforcement of the security of energy supply	Energy suppliers	Existing/planned	Ongoing from 2010
<b>Development and enabling of environmentally beneficial electricity storage</b>	Financial	Development and protection of storage units for the integration of renewable energies	Energy suppliers	Existing/planned	Ongoing from 2010

- Spain:** The National Renewable Energy Action Plan of Spain foresees that the share of renewables in the annual average electricity demand will be close to 40% by 2020. The breakdown between different renewable energy technologies shows that wind energy has the lion share of the whole RE production (in the order of 52%), and is followed at a high distance from hydro, solar thermoelectric and solar photovoltaic which have a share of respectively 8.3%, 3.8% and 3.6% of gross total electricity generation. The National Electricity Balance of Spain is presented in Table 2.2. below:

**Table 2.2.** National Electricity Balance of Spain (SPAIN'S NATIONAL RENEWABLE ENERGY ACTION PLAN 2011-2020, 30 June 2010)

GWh	2005	2010	2015	2020
Coal	81,458	29,710	33,630	33,500
Nuclear	57,539	56,000	55,600	55,600
Natural Gas	82,819	108,829	121,419	141,741
Petroleum products	24,261	18,535	9,381	8,721
Renewable Energies	41,741	82,631	113,325	152,835
Pumped hydroelectric	5,153	3,640	6,577	8,023
Gross generation	292,971	299,345	339,931	400,420
Consumption during generation	11,948	9,300	8,610	8,878
Net generation	281,783	290,045	331,321	391,542
Energy consumed by pumping	6,360	5,200	9,396	11,462
Exchange balance	-1,344	-8,000	-11,285	-25,199
Demand (bc)	274,080	276,845	310,640	354,882
Consumption processing sectors	5,804	5,314	5,800	5,800
Losses transport, distribution	25,965	25,520	28,065	31,138
FINAL ELECTRICITY DEMAND	242,310	246,011	276,775	317,944
Increase over preceding year	4.58%	0.80%	2.69%	2.95%
% renewables/gross production	14.7%	27.6%	33.3%	38.2%

According to the Spanish National Renewable Energy Action Plan, the share of energy from renewable energy sources in the gross final consumption of energy was 8.7% in 2005 (base year). The target for energy from renewables in gross final consumption of energy for the year 2020 was 20%, while the total expected adjusted energy consumption in year 2020 will be 97,041 ktoe, from which 19,408 ktoe will come from renewable energy sources.

Spain's target and estimated trajectory of energy from renewable energy sources in heating and cooling, electricity and transport are presented in the following Table 2.3. below:



**Table 2.3.** Spain's target and estimated trajectories in heating / cooling, transport and electricity (SPAIN'S NATIONAL RENEWABLE ENERGY ACTION PLAN 2011-2020, 30 June 2010)

	2005	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Renewable Energy Sources - Heating & Cooling (15) (%)	8.8%	11.3%	11.7%	12.0%	12.5%	13.2%	14.0%	14.9%	15.9%	17.0%	18.1%	18.9%
Renewable Energy Sources - Electricity (16) (%)	18.4%	28.8%	29.8%	31.2%	31.9%	32.9%	33.8%	34.3%	35.7%	36.9%	38.2%	40.0%
Renewable Energy Sources - Transport (17) (%)	1.1%	6.0%	6.1%	6.5%	6.5%	8.2%	9.3%	10.4%	11.1%	12.0%	12.7%	13.6%
Overall Renewable Energy Source share (18) (%)	8.3%	13.6%	14.2%	14.8%	15.4%	16.5%	17.4%	18.3%	19.4%	20.4%	21.5%	<b>22.7%</b>
<i>Of which from cooperation mechanism (19) (%)</i>			0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%		0.0%
<i>Surplus for cooperation mechanism (20) (%)</i>			3.2%	3.9%	3.3%	4.4%	3.6%	4.5%	3.3%	4.3%		2.7%
As Part B of Annex I to the Directive			2011-2012		2013-2014		2015-2016		2017-2018			2020
			$S_{2005} + 0.20 (S_{2020} - S_{2005})$		$S_{2005} + 0.30 (S_{2020} - S_{2005})$		$S_{2005} + 0.45 (S_{2020} - S_{2005})$		$S_{2005} + 0.65 (S_{2020} - S_{2005})$			$S_{2020}$
RES minimum trajectory (21) (%)			10.96%		12.09%		13.79%		16.05%			20.00%
RES minimum trajectory (ktoe) [2-year arithmetical average, except in 2020]			10,164		11,350		13,073		15,372			19,408

(15) Share of renewable energy in heating and cooling: gross final consumption of energy from renewable sources for heating and cooling (as defined in Articles 5(1)b) and 5(4) of Directive 2009/28/EC) divided by gross final consumption of energy for heating and cooling. Line (A) from Table 4a divided by line (1) of Table 1.

(16) Share of renewable energy in electricity: gross final consumption of electricity from renewable sources for electricity (as defined in Articles 5(1)a) and 5(3) of Directive 2009/28/EC) divided by total gross final consumption of electricity. Row (B) from Table 4a divided by row (2) of Table 1.

(17) Share of renewable energy in transport: final energy from renewable sources consumed in transport (cf. Article 5(1)c) and 5(5) of Directive 2009/28/EC) divided by the consumption in transport of 1) petrol; 2) diesel; 3) biofuels used in road and rail transport and 4) electricity in land transport (as reflected in row 3 of Table 1). Line (J) from Table 4b divided by row (3) of Table 1.

(18) Share of renewable energy in gross final energy consumption. Row (G) from Table 4a divided by row (4) of Table 1.

(19) In percentage point of overall RES share.

(20) In percentage point of overall RES share.

(21) As per the definition in Annex I.B of Directive 2009/28/EC.



Measures and policies to support the achievement of Spain's targets in the renewable energy sector are presented in the following Tables.

**Table 2.4.** General measures (SPAIN'S NATIONAL RENEWABLE ENERGY ACTION PLAN 2011-2020, 30 June 2010)

Name and reference of the measure	Type of measure (*)	Expected result (**)	Targeted group and/or activity (***)	Existing or planned	Start and end dates of the measure
1. Develop a suitable framework whereby to simplify, standardize and unify administrative procedures for the authorization of renewable energy installations, including simple notification.	Regulatory	Ease administrative burden, reduce red tape for administrative authorization	Public administrations	Existing and planned	2010 -2020
2. Develop a simplified regulated procedure whereby to secure administrative authorisation for renewable energy projects for thermal applications.	Regulatory	Expedite the issue of Administrative authorisation	Public administrations	Planned	Not defined
3. Support R&D-Innovation in energy storage systems.	Financial	Enhanced capacity for the integration of renewable energies in the electricity system.	Public administrations Technological centres	Planned	2012-2020
4. Maintain active public participation in R&D-Innovation in the renewable energies sector by setting up annual support programmes for priority industrial technological development initiatives designed to reduce generation costs,	Financial	Enhance the competitiveness of the more mature renewable energies. Full competitiveness in	Public administrations	Existing and Planned	2011 - 2020



mainly in the wind and solar sectors.		the case of wind energy.			
5. Develop lines of scientific research and innovation which promote the technological development of prototypes to harness marine renewable energies	Regulatory	Achieve commercial implementation of the technology	Technologists, development of national prototypes	Planned	Not defined
6. Develop specific marine technologies especially targeting deployment of projects to harness renewable energies on the high sea (wind, wave energy, etc.).	Financial	Increase the potential of marine renewable energies	Technologists, technological centres	Planned	2011 - 2020
7. Financial support for the implementation of high-level and very specialised experimental platforms at national level with international recognition	Financial	Provide incentive for R&D, Innovation and enhance technological competitiveness	Public administrations	Planned	2011 - 2020

(\*) Indicate if the measure is (predominantly) regulatory, financial or soft (i.e. information campaign).

(\*\*) Is the expected result behavioural change, installed capacity (MW; t/year), energy generated (ktoe)?

(\*\*\*) Who are the targeted persons: investors, end users, public administration, planners, architects, installers, etc.? or what is the targeted activity/sector: biofuel production, energetic use of animal manure, etc.)?



**Table 2.5.** Measures in the field of electricity generation using renewables (SPAIN'S NATIONAL RENEWABLE ENERGY ACTION PLAN 2011-2020, 30 June 2010)

Name and reference of the measure	Type of measure (*)	Expected result (**)	Targeted group and/or activity (***)	Existing or planned	Start and end dates of the measure
1. Change to a smart grid system of transmission and distribution	Regulatory	Better adaptation to supply and demand for electrical energy	Electricity system operators.	Planned	2012 -2020
2. Promote facilities generating electricity for own use from renewable sources by setting up better systems based on net balance and compensation for energy balances.	Regulatory	Limit energy demand on the system and evolve towards better management of demand	The General State Administration Electricity system operators Electricity traders	Planned	2011 - 2020
3. Establish a remuneration framework which is stable, predictable, flexible, controllable and secure for developers and the electricity system.	Regulatory Financial	Foster investment in the sector. Move the economy	The General State Administration	Existing	2010-2011
4. Review current planning for the gas and electricity sectors (approved in May 2008 for the 2008-2016 period) and properly develop electricity transmission infrastructure.	Regulatory Financial	Guarantee the transmission of electricity generated from renewable sources	The General State Administration	Existing and Planned	2010 - 2012



5. Specific planning of electricity transmission infrastructures linked to marine projects (wind, wave energy, etc.) taking account of progress in administrative procedure. Possibility of establishing offshore electricity transmission corridors to offshore project site.	Regulatory	Removal of barriers hindering the development of marine renewable energy projects	The General State Administration	Planned	2011 - 2020
6. Establish new international interconnections (especially with France).	Financial	Enhanced capacity for the integration of renewable energies in the electricity system.	European Commission	Planned	2010 - 2020
7. Increase in energy storage capacity through the start-up of new pumping plants.	Regulatory	Enhanced capacity for the integration of renewable energies in the electricity system.	The General State Administration Developers	Existing	2010 - 2020
8. Better management of demand in real time, facilitating participation of the end electricity user through measures aimed at flattening the demand curve (charging of electrical vehicle batteries and other initiatives).	Regulatory	Enhanced capacity for the integration of renewable energies in the electricity system.	The General State Administration	Planned	2011 - 2020
9. Establishment of a specific quota for experimental projects.	Regulatory	Facilitate the launching of emerging	The General State Administration	Planned	2010 - 2011



		technologies			
10. New regulations to facilitate the connection of electricity generation facilities with low-power renewable energies associated with consumption centres interconnected with the electricity grid (especially low-voltage).	Regulatory	Lessen administrative redtape	The General State Administration	Planned	2010 - 2011

(\*) Indicate if the measure is (predominantly) regulatory, financial or soft (i.e. information campaign).

(\*\*) Is the expected result behavioural change, installed capacity (MW; t/year), energy generated (ktoe)?

(\*\*\*) Who are the targeted persons: investors, end users, public administration, planners, architects, installers, etc.? or what is the targeted activity/sector: biofuel production, energetic use of animal manure, etc.)?



**Greece:** The National Renewable Energy Action Plan of Greece describes the procedures and goals of the country in order to promote the penetration of Renewable Energy Sources and meet the obligations imposed by the 2009/28/EC Directive. According to the Greek National Renewable Energy Action Plan, the share of energy from renewable energy sources in the gross final consumption of energy in the country was 6.9% in 2005 (base year). The target for energy from renewables in gross final consumption of energy for the year 2020 was 18%, while the total expected adjusted energy consumption in year 2020 will be 24,114 ktoe, from which 4,341 ktoe will come from renewable energy sources.

Greece's target and estimated trajectory of energy from renewable energy sources in heating and cooling, electricity and transport are presented in the following Table 2.6. below:

**Table 2.6.** Greece's target and estimated trajectories in heating / cooling, transport and electricity (National Renewable Energy Action Plan in the Scope of Directive 2009/28/EC, July 2010).

%	2005	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
RES-H&C <sup>12</sup>	12,76%	14,7%	15,7%	16,2%	16,8%	17,3%	17,9%	18,3%	18,4%	18,8%	18,9%	19,7%
RES-E <sup>13</sup>	8,03%	13,3%	15,7%	18,8%	21,8%	25,1%	27,6%	29,7%	31,8%	33,7%	36,7%	39,8%
RES-T <sup>14</sup>	0,02%	1,7%	3,3%	4,1%	4,8%	5,6%	6,3%	7,1%	7,8%	8,6%	9,4%	10,1%
Overall RES share <sup>15</sup>	6,96%	8,0%	8,8%	9,5%	9,9%	10,5%	11,4%	12,4%	13,7%	14,6%	16,0%	18,0%
<i>(Calculation Tables 4a and 4b are expected to guide the preparation of Table 3)</i>												
<i>Of which from cooperation mechanism<sup>16</sup></i>												
<i>Surplus for cooperation mechanism<sup>16</sup></i>		1,2%	1,8%	2,3%	3,1%	3,7%	3,9%	3,8%	3,3%	3,2%	2,9%	2,2%

<sup>12</sup> Share of renewable energy in heating and cooling: gross final consumption of energy from renewable sources for heating and cooling (as defined in Articles 5(1)(b) and 5(4) of Directive 2009/28/EC) divided by gross final consumption of energy for heating and cooling. Line (A) from Table 4a divided by line (1) of Table 1.

<sup>13</sup> Share of renewable energy in electricity: gross final consumption of electricity from renewable sources for electricity (as defined in Articles 5(1)(a) and 5(3) of Directive 2009/28/EC) divided by total gross final consumption of electricity. Row (B) from Table 4a divided by row (2) of Table 1.

<sup>14</sup> Share of renewable energy in transport: final energy from renewable sources consumed in transport (cf. Article 5(1)(c) and 5(5) of Directive 2009/28/EC) divided by the consumption in transport of 1) petrol; 2) diesel; 3) biofuels used in road and rail transport and 4) electricity in land transport (as reflected in row 3 of Table 1). Line (J) from Table 4b divided by row (3) of Table 1.

<sup>15</sup> Share of renewable energy in gross final energy consumption. Row (G) from Table 4a divided by row (4) of Table 1.

<sup>16</sup> In percentage point of overall RES share.

Measures and policies to support the achievement of Greece's targets in the renewable energy sector are presented in the following Table.



**Table 2.7.** Selected Measures and Policies of the Greek National Renewable Energy Action Plan (National Renewable Energy Action Plan in the Scope of Directive 2009/28/EC, July 2010).

Name and reference of the measure	Type of measure (*)	Expected result (**)	Targeted group and/or activity (***)	Existing or planned	Start and end dates of the measure
1. Application of L. 2773/99 “Liberalization of the Electricity Market – Regulation of Energy Policy issues and other provisions” L.2244/94 “Regulation of power generation issues from renewable energy sources and conventional fuels and other provisions” and L.3468/06 “Generation of electricity from renewable energy sources and through high – efficiency co-generation of electricity and heat and miscellaneous provisions”	Regulatory		Investors, Public administration	Existing	1994 and onwards
2. L.3734/09 “Promotion of co-generation of two or more energy sources, regulation of issues related to Mesochora hydroelectric plant and other provisions” and L.3851/2010 “Accelerating the development of Renewable Energy Sources to deal with climate change and other regulations in topics under the authority of MEECC”	Regulatory		Investors, Public administration	Existing	2009 and onwards
3. Feed-in tariff scheme per kWh of electricity	Financial		Investors	Existing	1994 and



produced by RES (L.2244/94, 3468/06 and 3851/10)					onwards
4. Development Laws 1892/90, 2601/98, and 3299/04	Subsidy of the cost of the investment plan, leasing, tax deduction		Investors	Completed	
5. L.3855/10 “Measures to improve energy efficiency in end-use, energy services and other provisions”, articles for public buildings and the ESCO market	Regulatory		End-consumers, energy companies, utilities, public administration	Existing	2010 and onwards
6. Special Physical Planning Framework for the development of RES and land management (OG B 2464/08)	Regulatory		Investors, public administration	Existing	
7. Special Programme for the deployment of PV of up to 10 kW on buildings and especially roofs	Feed-in tariff scheme		End consumers, household sector, small business	Existing	2009 - 2019
8. Mandatory deadlines for RES licensing procedure (L.3734/09 & L.3851/10)	Regulatory		Investors, public administration	Existing	2009 and onwards
9. Tendering procedure for the construction and operation of off-shore wind farms (L.3851/10)	Regulatory		Investors, public administration	Planned/ Existing	
10. OPC – Operational Program for Competitiveness 3 <sup>rd</sup> Framework Programme	Financial		Investors, public administration, engineers	Completed	2000 - 2006



11. Exemption of electrical and/or hybrid and/or low emission vehicles from the fuel consumption tax, the additional special tax, the circulation tax, and/or the registration tax (L.2052/92, 3851/10 and 2960/01)	Regulatory Financial		End users	Existing	To the present
12. Definition of technical specifications for energy efficient vehicles, share of clean vehicles, replacement of old vehicles, public procurement based on fuel economy label and training on eco-driving for application to the entire public sector (L.3855/10)	Regulatory		Public administration	Existing / Planned	
13. Guidelines for licensing and development of conventional power producers in order for them to be flexible and support the large-scale wind penetration	Regulatory		Investors, public administration, planners	Planned	2010 - 2012
14. Guidelines and directions for the licensing RES – E based on the energy mix included in the NREAP	Regulatory		Investors, public administration	Planned	2010 - 2020
15. Development of storage facilities in the interconnected system by exploiting hydro pumping system at existing large hydro plants and new installations	Technical	1580 MW of Renewable Energy	Public administration, planners	Existing / Planned	2010 - 2020
16. Further development of the distribution grid based on the smart grids principles	Technical		Investors, public administration, planners	Planned	2010 - 2020

(\*) Indicate if the measure is (predominantly) regulatory, financial or soft (i.e. information campaign).

(\*\*) Is the expected result behavioural change, installed capacity (MW; t/year), energy generated (ktoe)?

(\*\*\*) Who are the targeted persons: investors, end users, public administration, planners, architects, installers, etc.? or what is the targeted activity/sector: biofuel production, energetic use of animal manure, etc.)?

## 3.2. EU policies for the promotion of Energy Storage (including hydrogen)

Energy storage, both short and longer – term has been recognized as a prerequisite for higher RES penetration and grid balancing in the EU. The objective of this paragraph is to present policies adopted by the European Commission and the Member States as well that support the promotion of energy storage. Focus will also be given in the targeted countries of DEMO4GRID project namely Austria, Spain and Greece.

Energy storage has a growing role in the energy transition of the European Commission. It contributes in the following:

- Greenhouse Gases Reduction
- Decarbonisation of other economic sectors such as the transport and industrial sector
- Contributes in more electricity in the energy consumption
- It is necessary to bring up changes in the electricity mix: in more detail it helps phasing out conventional generation and introducing more intermittent renewables

The following steps related to energy storage and its promotion to the European energy system have been made so far:

- Definition of Energy Storage and Set – Up of basic Policy Principles
- Electricity market design
- Storage technologies initiatives have been developed
- Sector coupling (Electricity, Gas, Heating, Industry, Transport, Agriculture)
- Support of Energy Storage Projects
- Discussion with stakeholders

With respect to the latter step (discussion with stakeholders), the European Commission asked stakeholders to answer to the following questions:

- Why does the energy system need storage?
- What are the barriers (regulatory, fiscal, economic, technical) in the deployment of energy storage?
- Is the regulatory framework sufficient to ensure that markets can deploy energy storage?
- Should the EU do further efforts? What type of actions / policy options should be considered?

In the following paragraphs the above mentioned six (6) steps related to energy storage and its promotion as a means of grid balancing amongst other, will be analyzed in detail:

- *Definition and Policy Principles:* According to the Proposal of Electricity Directive (recast), Article 2, “Energy Storage” means, in the electricity system, deferring an amount of the electricity that was generated to the moment of use, either as final energy or converted into another energy carrier. The following Principles support the market development of energy storage:
  - It could contribute to energy security and decarbonization of the electricity system or even of other sectors
  - It should be allowed to fully participate in electricity markets
  - It should participate and be rewarded on equal footing to providers of flexibility services (e.g. demand response)
  - The cost-efficient use of decentralized energy storage and its integration into the system should be enabled in a non-discriminatory way
- *Electricity Market Design:* The Electricity Market Design proposes specific rules that will facilitate flexibility and energy storage:
  - It ensures the neutrality of network operators vis-à-vis new business activities in storage: In more detail, when a network operator need energy to manage its network, this energy is procured from market participants and only in case there are no market interests at all, a regulatory authority may grant a temporary derogation
  - Regulatory authorities should ensure that charges for access to network do not discriminate energy storage
  - Storage deployment will be facilitated by the fact that stricter rules on RES curtailment (in combination with higher targets on RES penetration) exist
  - In day ahead and intra-day market, energy trading should be as close to real time as possible and a bid size should not exceed 1 MW
  - Strengthening of short – term price signals will ensure that electricity prices provide correct and meaningful production and investment signals
  - Risk preparedness: all measure, including storage that will help in avoiding crisis or containing a crisis are equally relevant
- *Storage technologies initiatives:* The following energy storage technologies initiatives already exist at EU level:
  - Technological innovation in energy storage is strongly supported and financed by the EU under the **HORIZON 2020 Programme**
  - The collaboration within the **Strategic Energy Technology Plan (SET Plan)** enables EU players to define priorities on Research and Innovation and collaborate in the energy sector. This includes also the action on **Smart Energy System** and the action on **Batteries**

- The technologies related to the use of electricity to produce gas, mainly hydrogen are managed through a specific programme office, the **Fuel Cells and Hydrogen Joint Undertaking (FCH JU)**
- The **EU Battery Alliance** aims to create a competitive and sustainable battery cell manufacturing in Europe, supported by a full EU – based value chain. The Action Plan supporting this Alliance was published by the European Commission on May 2018
- *Sector coupling:* The objectives of coupling between different sectors (electricity, heating and cooling, transport, industry and agriculture) are the following:
  - The basic concept lies in both physical and market coupling of the electricity, gas, heating and cooling with other economic sectors (industry, transport, agriculture)
  - It is a tool contributing to the decarbonization of the energy system, while in parallel provides the necessary flexibility to the electricity and has networks (e.g. excess of decarbonized electricity is transformed to other forms of energy for temporary storage, or direct use, or for the production of useful products)
  - There are several studies available at EU level, aiming to identify:
    - Existing regulatory barriers and potential gaps to the coupling, in particular of electricity, gas and heating sectors
    - Recommendations to overcome barriers / fill the gaps
- *Support of Energy Storage Projects:* The following support is given to energy storage projects by the EU:
  - Energy Storage Projects in electricity can also become Projects of Common Interest (PCIs)
  - In the context of the TEN-E infrastructure framework, large storage projects, above 225 MW, may be included in the selection process for the PCI. Smaller storage units may be part of smart grid PCIs
  - In November 2017, the European Commission published its third list of PCIs, which includes 15 storage projects in electricity (11 projects on pumped hydro storage and 4 projects on compressed air energy storage)
- *Discussion with Stakeholders:* The following interaction with different stakeholders and the EC has been done:
  - High Level Roundtable on Energy Storage and Sectoral Integration was organized on March 2018. Representatives from industry, research and the European Commission participated in the discussions related to the role of energy storage and sectoral integration in the transition to low-carbon economy
  - Discussions with Member States at the Electricity Co-ordination Group took place on July 2018

(Source: Reflections on Energy Storage, Yolanda Garcia Mezquita, ENER-B4, Florence Forum, May 2018).

In more detail, the following policies aiming to regulate the contribution of energy storage in the EU electricity market have been designed by the Commission:

- **Balancing:** All market participants shall aim for system balance: Financial responsibility is introduced
- **Day ahead and intra-day:** the imbalance settlement is set at 15 minutes and bid size up to 1 MW
- **Price caps:** No maximum (or lower of the value of lost load), no minimum (or minus 2000€)
- **Priority dispatching:** Only for small RE producers, high efficiency CHP and “old” RE & CHP assets
- **Curtailment of redispatching:** when it is economically efficient and does not exceed 5%
- **Bidding zone:** shall be based on long-term, structural congestions
- **Network congestion:** to be addressed with non-discriminatory market – based solutions
- **Grid fees:** To reflect actual costs; non – discriminatory (including energy storage), not distance related, customer profile may have an impact on the fees (including energy storage), procured storage services would be included in the system operators cost base, recommendation on the structure of fees by ACER
- **Regional TSO cooperation:** by performing actions of regional relevance
- **The “EU DSO entity”:** a) coordinate operation and planning of T&D networks, b) integration of renewable energy sources, distributed generation, energy storage etc.
- **Network codes:** The European Commission may adopt delegated acts, such as network codes on the basis of text proposals developed by the ENTSO for Electricity, or by the EU DSO entity and ACER

In the next sections, the initiatives, measures and policies related to energy storage and hydrogen in particular, at national level of the three targeted countries (Austria, Spain and Greece) will be presented.

### 2.2.1 Austria

#### *Austrian Climate and Energy Strategy #mission2030-objectives*

- Share of 44-50 % renewable energy in gross final energy consumption by 2030 (currently 33.5 %)
- 100 % of total national electricity consumption from renewable energy sources by 2030 (currently 72 %)
- Transition to low and zero-emission vehicles via alternative propulsion systems & fuels based on renewable energies (battery vehicles, fuel cell vehicles, bio-gas and liquid bio-fuels).



### ***National Hydrogen Strategy***

- This strategy is being developed by BMVIT and the Ministry for Sustainability and Tourism in close cooperation with science and industry until the end of 2019.
- The strategy is part of the contents of the European Hydrogen Initiative initiated by Austria during the EU-presidency. The elaborated targets and measures will be included in the National Climate and Energy Plan, which will be submitted to the EC by the end of this year which will already be partially implemented in the Renewable Development Act (EAG) 2020.
- 4 working groups:
  - Infrastructure, Generation and Storage
  - Greening the Gas
  - Hydrogen in industrial processes
  - Fuel cells and hydrogen end-use (mobility and buildings)

### ***European Hydrogen Initiative***

- **Objective:** Maximise the great potentials of sustainable hydrogen technology for the decarbonisation of multiple sectors, the energy system and for the long-term energy security of the EU
- **Signatories:** 23 EU member states and more than 100 companies and research organizations
- **Conversion of Hydrogen to renewable natural gas:** Austria explores the most effective conversion of renewable hydrogen into synthetic methane and other renewable fuels
- **Sector integration and coupling:** Austria emphasises the role of hydrogen as a promising link between the electricity, industry and mobility sectors, opening new windows of opportunity in energy flexibility, availability, security, as well as improved efficiency and cost-effectiveness in the energy transition, contributing to the decarbonisation of the energy
- **Industry:** Austria promotes the use of renewable hydrogen as well as derived products in industrial processes.

### ***Austria as potential Hydrogen Valley in the heart of Europe***

- Bridging many neighbouring countries including eastern Europe
- Central player of the European natural gas grid with huge storage capacity
- High share in renewable energy sources: in transport 2nd in Europe, approaching 100 % renewable electricity
- Strong energy sector and vehicle industry as well as high R&D-competence
- Complementarity with other European counties as provider of supply components and engineering services

### ***Challenges***

- Dependency on Energy Import: Fossil fuels worth around € 400 billion are imported annually, which accounts for more than 25 % of all imports into the EU

- Emission reduction: Simultaneous reduction of greenhouse gases, pollutants and noise to achieve EC climate goals, COP21 objectives and clear air regulations
- Storage of intermittent renewable energy sources, setup of nationwide grid of hydrogen refuelling stations, development of cheap and reliable fuel cells

### ***Austrian Automotive Industry***

- Automotive industry is a global key industry sector and one of the most successful industrial branches in Austria
- 75000 employees and 700 companies
- Turnover of 21.5 Billion €/year
- Automotive export revenues 3 times higher than import expenditures
- 26 % of employees in R&D and 21,459 € for R&D per employee (industrial average of 8,700 €).

### **2.2.2. Spain**

#### **Policies enabling demand response in Spain**

Currently, in Spain the only possibility to provide grid services using loads<sup>1</sup> is called interruptibility grid service and is meant for situations where there is not enough generation to supply the demand. This could be due to a peak of extraordinary consumption, or a sudden loss of production, which are not usual events in Spain due to the sufficient capacity of the generation system. The service is regulated by Order IET/2013/2013<sup>2</sup>, which establishes the competitive mechanism of assignation of the interruptibility demand management grid service. The service awards large industrial consumers and has been used very few times in the past decade until 2018, when the transmission system operator (TSO) Red Eléctrica de España decided to use it with economic criteria to lower electricity prices instead of restricting it to shortcoming technical issues. Since the beginning of 2018, the service has been requested to the providers more times than in the last decade. The service requires decreasing consumption from loads through 5 MW or 90 MW packages and with three different response times: (a) instantaneous execution without pre-order (response within seconds), (b) fast execution (minimum pre-order of 15 minutes) and (c) hourly execution (minimum pre-order of 2 hours) with tenders every year to select the providers and set the remuneration for the available capacity offered (EUR/MW) and for the energy reduction (EUR/MWh). This scenario is feasible for participation of multi MW electrolyzers, but a service availability of more than 95% is

---

<sup>1</sup> Smart Energy Demand Coalition (SEDC), “Explicit Demand Response in Europe - Mapping the Market 2017”, 6<sup>th</sup> April 2017.

<sup>2</sup> Orden IET/2013/2013, de 31 de octubre, por la que se regula el mecanismo competitivo de asignación del servicio de gestión de la demanda de interrumpibilidad, Spanish Official Journal (BOE), No. 262, 1 November 2013.

required by the TSO, which would mean an electrolyser of minimum 5 MW in continued production being able to reduce power consumption in 5 MW when requested, with the consequent operational costs linked to such mode of operation. This is feasible for a large electrolyser providing a continuous stream of hydrogen, for example in a chemical plant, with a huge demand of this fuel. However, this use is already mature (stationary operation) and restricted to specific niche markets in industries with a need for hydrogen for their processes but not appropriate to cover the large upcoming hydrogen markets to be deployed in the EU, with smaller demands. This is the case of mobility with FCEVs, which do not require such an amount of this fuel yet. Thus, the interruptibility grid service is not considered as the option to capture revenues in a case study meant to analyse the potential to serve mobility with FCEVs.

A more attractive option to implement demand response with flexible multi-MW loads to provide grid services in Spain would be the possibility to adjust grid frequency through the secondary regulation market (as it is possible in Austria for example with the aFRR). This is because the provision of the service includes a remuneration not only for power reductions (as it is the case of interruptibility) but also for increases through 10 MW packages with a time response of less than 5 minutes. Currently, only generators are only allowed to participate in the secondary regulation service, so loads such as electrolysers would be excluded from application, which limits the possibilities for demand response implementation in the country as a complementary tool to face the increasing penetration of renewable generation in the electricity system. However, having a look at the trends in other EU countries<sup>1</sup> where there are already grid services in place providing remuneration to loads increasing or decreasing consumption by packages of more than 1 MW or 5 MW to regulate frequency, accommodate RES and comply with the EU goals in this matter, it seems Spain should require soon a similar approach to avoid substantial updates in grid infrastructures.

### Potential for hydrogen markets

Besides mature markets (e.g. hydrogen production required in chemical plants), in Spain the greatest potential in the last years has been towards hydrogen mobility. However, Spain is still lagging behind EU initiatives in terms of hydrogen refueling infrastructure, which concentrate mainly in the countries in the centre and north of Europe. Table shows the expected amount of HRS in the EU in 2020, 2025 and 2030 in the pioneering countries in the introduction of FCEVs<sup>3 4,5,6,7</sup>.

Table 2.8. Perspectives for the cumulated number of HRS deployed in EU countries

	Belgium	Germany	UK	Netherlands	Denmark	Sweden	Norway	France	Italy	Total (EU)
2020	25	100	65	20	15	15	25	29	20	314
2025	75	400	300	80	185	185	308	355	197	2085
2030	150	900	1100	200	500	500	833	600	442	5225

<sup>3</sup> Mobility Belgium, "National Implementation Plan Hydrogen Refuelling Infrastructure Belgium", HIT-2 project, December 2015

<sup>4</sup> FCH 2 JU H2ME project. [Online] available: <http://h2me.eu/about/hydrogen-refuelling-infrastructure/>

<sup>5</sup> Mobilita H2 Italy. [Online] available: <http://www.mobilitah2.it/plan>

<sup>6</sup> Mobilité Hydrogène France, Element Energy, "H2 Mobilité France. Study for a Fuel Cell Electric Vehicle national deployment plan", 2014.

<sup>7</sup> J. Owen-Jones, "France has its very first H2 refueling station", GasWorld, April 2017.

Inside this framework, Spain is trying to join these initiatives so as not to remain isolated from the deployment of hydrogen corridors which link these EU countries and specifically, to create links with France. Now, six HRS are available in Spain for refueling and four new ones are foreseen by 2020 to link the North of the country with the South of France through H2PiyR project<sup>8</sup>. These initiatives aim at tackling the ambitious expectations set out by the Spanish Government in 2016 of 20 HRS in 2020<sup>9</sup>. The main barrier for the introduction of hydrogen mobility in Spain, as it is in other countries, is the high total costs of ownership (TCO) for the FCEVs and specially the refueling infrastructure. FCEVs are available in the market with similar performance to conventional ICE vehicles (e.g. Hyundai ix35, Toyota Mirai, Honda Clarity FCV or Renault Kangoo ZE H2) and better CAPEX and OPEX comes mainly from the fuel cell which converts the hydrogen into electricity onboard. There, it is still need to reduce the presence of Platinum group metals to reduce CAPEX in the fuel cell as well as to work on durability to increase lifetime of fuel cell stacks and reduce maintenance costs (i.e. OPEX). In the case of the refueling infrastructure, if built to be fed with green hydrogen from renewable energy by means of electrolysis, it involves the CAPEX of the electrolyser and the cost of hydrogen storage and the HRS (which includes a compression installation) which in case of supply at 700 bar (latest standard pressure for refueling in the EU) means more than 1000 kEUR for a supply of around 200 kg of hydrogen per day (an average car in the EU travels 12000 km/year, which means 2.3 kg of hydrogen demand per week if 1 kg of this fuel allows to drive for 100 km). These costs are even increased if the HRS is small, as economies of scale strongly benefit FCH technologies.

### **2.2.3. Greece**

The main policy adopted by Greece to facilitate the deployment of energy storage in its national energy system is related to provisions introduced in Greek Laws 3468/2006 and 3851/2010 with respect to the operation of hybrid power systems in the non-interconnected electricity networks of the country.

More specifically, Greece was one of the first EU Member States to introduce specific policies and measures promoting energy storage as a medium of increasing Renewable Energy Sources penetration, mainly in the weak electricity grids of islands. According to this legislative and regulatory framework, the operation of hybrid power stations comprising of at least one renewable energy source and at least one energy storage device is allowed in all autonomous (non-interconnected) electricity networks of the country.

According to the provisions of the above mentioned legislation, a feed-in tariff model is introduced for the promotion of hybrid power stations in Greece; the tariff being calculated differently for each individual isolated (autonomous) electricity network, as a result of a detailed energy study and simulations taking mainly into

---

<sup>8</sup> POCTEFA H2PiyR project. [Online] available: [www.h2piyr.eu](http://www.h2piyr.eu)

<sup>9</sup> Ministry of Economy, Industry and Competitivity, "Spanish National Action Framework for Alternative Energy in Transport", 2016.

account the marginal system price, the actual cost for energy production and the existing renewable energy penetration. Using this legislative and policies measures the following hybrid power stations operate / have been designed in Greece:

- Tilos island Hybrid Power Station comprising wind, PV and batteries (in operation)
- Ikaria Hybrid Power Station comprising wind and pumped hydro (under construction)
- Crete Hybrid Power Station comprising wind and pumped hydro (under permitting procedure)
- Ai Stratis Hybrid Power Station comprising Wind, PV and Batteries (design of the project completed)
- The Greek Government has announced that three additional small Greek island will be transformed into Green Energy Islands, through the introduction of energy storage technologies in combination with RES, namely Symi, Astypalaia and Kastelorizo. There will be a tendering procedure for investors that will take over the implementation of these projects

The feed-in tariffs for hybrid power stations have not been set for all non-interconnected electricity of Greece, since this is a time consuming procedure, triggered by investors application for power production permits in each system. For the time being, the tariffs that have already been set in Greece range from 165 €/MWh to 234 €/MWh.

The technical specifications regarding the terms of operation and pricing, and the provisions set in the above described legislation have been designed mainly taking into account the energy storage technology of pumped – hydro. This fact creates significant problems in the economic viability of hybrid power stations using other energy storage technologies, including hydrogen.

In addition, by the Greek Law 4439/2016 the country adopts the EC Directive 94/2014 regarding alternative fuels infrastructure. All required technical specifications of vehicles Hydrogen Refueling Station infrastructure are set in this legislation. Unfortunately, the Greek state has not taken any other measures and policies to promote hydrogen, both as an energy storage medium and grid balancing method.

## 4. OVERVIEW OF EUROPEAN ELECTRICITY MARKETS AND PRICES


One of the most important parameters and input in the market potential assessment of hydrogen produced through electrolysis for grid balancing purposes is the identification of the methodology of operation of the European Electricity Markets

and especially the prices related to Renewable Electricity, including its short- and long – term variations. This is a critical parameter for the economic viability of the final product of DEMO4GRID project, namely a large-scale electrolyzer to provide grid balancing for the following reasons:

- The economic viability of hydrogen production through PAE for grid balancing applications is strongly related to the cost of electricity used to drive the electrolyzer. Therefore, the operation of the electrolyzer to provide grid balancing services through several applications that will be analyzed in Chapter 4, becomes economically favorable, when the cost of electricity is low
- In the Northern European countries and in general in countries with high RES (especially wind) penetration, there is an opportunity to buy electricity at very low (or even negative cost) at periods of high RES production and when the electricity demand is relatively low (e.g. during nighttime)
- On the other hand, hydrogen production to provide grid balancing services makes sense in financial terms, in countries that have low cost of electricity (with Greece being one among them) all year around
- Daily variations on the cost of electricity in countries with smart metering operation and the ability to change between electrical energy providers gives the opportunity to the producers of hydrogen through electrolysis to decide the periods of time in which they will operate in order to reduce their costs of electricity and come up with a more profitable business case
- In addition, another option for grid balancing is to sell electricity produced from hydrogen in fuel cells back to the grid. Electricity prices are important for this option as well, where hydrogen producers become electricity producers and they are able to select periods of low renewable energy production in order to sell electricity at higher prices.


#### 4.1. Overview of Electricity Prices for Industrial Electrolyzers at EU level

The FCH JU study entitled: “Water Electrolysis in the European Union”, representative data sets for different types of regulatory and pricing environment, values from five European member states were selected in order to analyze the available cost of electricity for industrial electrolyzers. The countries selected represented significant variations (by electricity price, penetration of renewables and overall market size) in order to come up with an overview of different cases and business development environments. As can be seen in Figure 3.1., a large range of electricity prices for industrial consumers is available in different Member States.




**Figure 3.1.** Average electricity cost to industrial electrolyzers in 2012 (Development of Water Electrolysis in the European Union Final Report, February 2014, prepared by E4tech Sàrl with Element Energy Ltd for the Fuel Cells and Hydrogen Joint Undertaking).

The large variation in electricity prices in different countries and in different periods of time and conditions results in a significant differentiation on the cost of hydrogen produced from electrolysis, depicted in Figures 3.2. and 3.3. since as will be analyzed in the following Chapters of this Deliverable, electricity prices are a critical factor affecting highly both total hydrogen production cost and the economic viability of the investment as well. It should be noted that in these Figures “RG only” refers to Renewable Generator.



**Figure 3.2.** Hydrogen production costs in 2012 for best case KPIs for Alkaline and PEM electrolyzers in different electricity market scenarios. (Development of Water Electrolysis in the European Union Final Report, February 2014, prepared by E4tech Sàrl with Element Energy Ltd for the Fuel Cells and Hydrogen Joint Undertaking).





**Figure 3.3.** Hydrogen production costs estimated for 2030 for the best case KPIs for Alkaline and PEM electrolyzers in different electricity market scenarios (Development of Water Electrolysis in the European Union Final Report, February 2014, prepared by E4tech Sàrl with Element Energy Ltd for the Fuel Cells and Hydrogen Joint Undertaking).

## 4.2. Identification of Electricity Prices for Industrial Electrolyzers in the targeted EU countries

The electricity prices for industrial electrolyzers in the remaining targeted EU countries, namely Austria and Greece (these prices were presented for Spain in the previous paragraph are the following:

### 3.2.1 Austria

Market conditions in Austria have changed significantly. The bidding zone integrity between German and Austrian electricity market has been suspended and replaced with a capacity market mechanism. This has led to significant price changes for wholesale electricity. Additionally, the market design for the Austrian regulatory energy market has been changed in 2018.

Both changes influence the business model of Demo4Grid. **Deliverable D3.3** is outlining the effects of these changes in detail and incorporates available market data (since changes are in effect) via a simulation in order to get a deeper understanding of revenue potentials and market restrictions.

Together with the TIWAG AG, a simulation based on past market data was designed and implemented. This simulation incorporates the new balancing power market design (introduced in summer 2018) and changes originating from the bidding zone separation of Austrian and German wholesale electricity market. Due to the new market design, price levels and bidding strategies have changed considerable.

The new simulation data is based on market information from October 2018 until March 2019. Although a full calendar year set of market data is not available yet,



relevant changes are incorporated in the available data and the results of the simulation incorporate actual market conditions.

### 3.2.2 Greece

The electricity prices for industrial customers in Greece vary according to: 1) grid connection status (low, medium or high voltage), 2) the required maximum capacity and 3) the usage factor (low or high). Currently, there are not provisions related to lower electricity prices for the operation of the electrolyzers in time periods and areas with excess renewable energy production and high curtailments in the regulatory framework of the country. The only exemption to that is the existence of specific provisions and high feed – in tariffs for selling electrical energy from hybrid power stations (combined RES and energy storage installations, which may include hydrogen as a storage medium) back to the grid. The feed – in tariff mentioned from the energy storage installations above, could reach up to 250 €/MWh.

Therefore, Greece cannot be considered currently as a Member State with a high market potential for Power to Hydrogen applications, with the potential exception of re-electrification systems in the autonomous, non – interconnected to the mainland grid, islands of the country.

To provide with an idea of the electricity costs for industrial electrolyzers for the country of Greece, the so-called BY pricing invoice of the Public Power Corporation (PPC) is presented in Table 3.1. This electricity pricing invoice is directed to commercial and industrial end – users at medium voltage, having a high usage factor of electrical energy.

**Table 3.1.** BY electricity pricing invoice of the Public Power Corporation (PPC) in Greece ([www.dei.gr](http://www.dei.gr))

Time Zone	Power Pricing (€/kW/month)	Energy Pricing (€/MWh)
7:00 – 23:00 on working days, all year around	8,00	
7:00 – 23:00 on working days, all year around		59.03
23:00 – 7:00 on working days, and on all weekends and public holidays		46.14

On top of the electricity prices related to the production and procurement of electrical energy, PPC pricing invoices have also regulated charges, which are presented in Table 3.2.

**Table 3.2.** BY regulated charges invoice of the Public Power Corporation (PPC) in Greece ([www.dei.gr](http://www.dei.gr))

	Transmission System	Distributed System		Other Charges (€/kWh)	Charges related to RES (€/kWh)	Common Benefit Services (€/kWh)
	Power Pricing (€/kW/month)	Power Pricing (€/kW/month)	Energy Pricing (€/MWh)			
Commercial	1.329	1.179	2.9	0.00007	0.00878	0.01790
Industrial	1.329	1.179	2.9	0.00007	0.00878	0.00691

## 5. BUSINESS CLIMATE FOR GRID BALANCING / CURRENT MARKETS FOR PRESSURIZED ALKALINE ELECTROLYZERS IN EUROPE

In this Chapter the analysis of the overall business climate including the current available markets for Pressurized Alkaline Electrolyzers and the identification of end – users for hydrogen per each application sector will be presented. This analysis is a significant part of the overall market potential assessment, since it identifies market target groups and specific clients to be contacted after the end of DEMO4GRID project, aiming at the commercialization of its final product. The business climate analysis for grid balancing and all the above mentioned components will be described in detail, categorized per application in the following sectors.

The advantages of producing hydrogen through water electrolysis in the grid balancing procedure were presented and fully analyzed in Chapter 1. The versatility of hydrogen applications is the strongest advantage, since it can be used as a fuel, can be injected to the natural gas grid, can be used as an industrial gas in many processes, provides an ideal solution for clean transport and can be re-electrified in fuel cells to produce power again. Moreover, hydrogen produced from electrolysis is an excellent medium to provide grid services and balancing and produce additional revenues.

The business climate for hydrogen production through water electrolysis to contribute to grid balancing was analyzed in detail in the “Study on early business cases for H<sub>2</sub> in energy storage and more broadly power to H<sub>2</sub> applications” prepared by TRACTEBEL and Hincio, which was funded by the Fuel Cells and Hydrogen Joint Undertaking (FCH JU) and supported by the European Commission.

The basic conclusion of the above mentioned study was that Power to Hydrogen is bankable already today. It has been concluded that the estimated cumulative electrolyzer capacity to be installed in Europe by 2025 is in the order of 2.8 GW. This estimation is based on sound economics and represents a total market value of € 4.2 bn. Even today, the total amount of profitable business cases in the field would be in the order of 1.4. GW, with a market value of €2.6 bn, if all these cases were realized.

As was already described in the previous Chapter of this Deliverable, the critical factor for the economic viability of such an investment is the Price of Electricity. According to this study, a total (baseload) electricity price in the order of 40 -50 €/MWh is required to build a profitable business case. This price includes the total cost of electricity needed to drive the electrolyzer, grid fees, all taxes and levies.

The most effective method to achieve profitability is to combine several revenue streams from different market applications that will be described in more detail in the next paragraphs. In European areas that have access to discounted electricity prices through valorization of local curtailed renewable electricity, the most bankable business cases identified for the short- and medium-term include mobility and industry as primary applications, such as regional hydrogen mobility deployment (irrespective of the end-user being cars or buses, or trucks), refineries and cooking oil production, complemented by hydrogen injection to the natural gas grid. The best payback time of the identified located business cases varies from 3 to 11 years depending on the primary application, having as a primary success condition, a gas grid injection tariff of at least 90€/MWh LHV.




The refinery business case is the only one that is not identified as profitable (as a stand-alone application) in the study. To bring this business case to breakeven today, a subsidy of at least 10% on capital investment costs would be required.

One of the basic conclusion of the study was that business cases that are based in single primary applications (selling hydrogen to industrial or mobility applications) will have good chances of profitability, but with higher payback periods compared to business cases that combine multiple revenue streams. The bankability of such application will be improved when including revenues from the provision of services to balance and improve the quality of grid frequency to the power system (frequency containment and/or restoration reserves). Such an approach contributes in decreasing payback times as well. These services, even though represent a relatively small share of the total revenues of the investment (between 10% and 30%), they also have a

sizeable and positive effect on net margin (+40% to +80%), since the additional cost needed to provide grid services is relatively low. The impact of including grid frequency / balancing services to the investment payback time is a reduction, ranging between 30% and 50%, and more specifically from 4-11 years, down to 3-8 years.

In the next Table 4.1. the profitability results for the three best short-term business cases assessed in the context of this study are presented.

**Table 4.1.** Profitability results of the three best short-term business cases of the study (STUDY ON EARLY BUSINESS CASES FOR H2 IN ENERGY STORAGE AND MORE BROADLY POWER TO H2 APPLICATIONS, FINAL REPORT, June 2017, prepared by TRACTEBEL and Hincio for FCH JU)

	 Semi-Centralised production for mobility (Albi, France)		 Food industry (Trige, Denmark)		 Refinery (Lubeck, Germany)	
Weighted Average Cost of Capital (WACC) on CAPEX: 5% Project lifetime: 20 years	2017	2025	2017	2025	2017	2025
Primary market H2 volume (t/year)	270	950	900	900	3 230	3 230
Average total electricity price for prim. market (€/MWh)	44	45	38	47	17	26
Net margin without grid services (k€/MW/year)	39	71	228	248	-146	30
Net margin with grid services (k€/MW/year)	159	256	373	393	-13	195
Share of grid services in net margin (%)	75%	72%	39%	37%	-	85%
Payback time without grid services (years)	11.0	9.0	4.6	3.7	-	8.4
Payback time with grid services (years)	8.0	4.5	3.4	2.7	-	3.5
Key risk factors	<ul style="list-style-type: none"> <li>• Taxes &amp; Grid fees</li> <li>• H2 price</li> <li>• Size of fleets</li> <li>• Injection tariff</li> <li>• Grid services revenues</li> </ul>		<ul style="list-style-type: none"> <li>• H2 price</li> <li>• Taxes &amp; Grid fees</li> <li>• Grid services revenues</li> </ul>		<ul style="list-style-type: none"> <li>• Taxes &amp; Grid fees</li> <li>• Grid services revenues</li> <li>• Carbon price</li> </ul>	

Source: Hincio

## 5.1. Power to Gas

This business case refers to the production of hydrogen through water electrolysis and its injection to the natural gas grid. This concept has been tested in small – scale first the last two decades. Currently, it is characterized as a secondary value stream, since it is considered insufficient to drive a solid business case on its own, but it can turn out to be very useful in creating opportunities to stack additional revenues on top of a primary value stream at very low marginal cost, resulting in a significant increase of the profitability of the investment.

Gas injection to the grid is an energy storage method, is being characterized as a large – scale application. In addition, this is a pathway for long – term storage of excess renewable electricity. The basic advantage of gas grid injection lies in the fact that no additional investments in infrastructure are required, since the already existing natural gas grid can be used for storage and transport medium for hydrogen as well. This method can therefore be applied in order to both store and transport very large quantities of excess renewable energy, which in several cases occur on a seasonal basis, over long distances, without introducing a need for building new connectors.

This energy storage method is being seriously examined in Germany, where large quantities of excess wind energy (produced in the North) that cannot be absorbed by the electricity grid of the country, cannot be easily transferred to the consumption centres of the South due to the lines congestion. The result of this situation is wind energy curtailment at a very high percentage. Of course, it can be easily understood that batteries are not an option for large – scale and long – term energy storage of the excess wind energy. Moreover, the construction of new electricity distribution lines is extremely challenging in terms of cost and public acceptance. Energy storage in hydrogen, followed by its injection to the natural gas grid is a potential solution to the above mentioned problems.

As described above the power to gas option has theoretically several advantages, but specific issues related to economic and regulatory matters should be solved in order to become a solid business case. In more detail, there is one barrier related to a regulatory limitation on the maximum hydrogen percentage that can be injected to the natural gas grid. There are also technical limits for specific natural gas end-users, the processes of which are not tolerant to high hydrogen content in the NG. The production of synthetic natural gas through methanation is a potential solution to overcome the limitations on maximum hydrogen content injected to the grid, but this option is associated with the introduction of additional costs and makes this business case economically unattractive.

The economic analysis of this study concluded that the power to gas option is not attractive, since without any kind of support or subsidies, the cost of hydrogen injected is comparable to the natural gas delivered by the pipeline. Therefore, in order to build solid power to gas business cases specific instruments should be introduced. There are two options:

- **A feed-in tariff (or injection tariff) scheme** for green hydrogen, which can operate on principles, which are similar to the scheme that already exists in several countries for biomethane. Currently, such a scheme does not exist for green hydrogen or low carbon hydrogen in any European country
- **A carbon price** that would apply (among others) as a tax on natural gas. Such a provision would help in reducing the cost between these two gases (natural gas and hydrogen)

The first option of introducing feed-in tariffs for green hydrogen, is considered to be the most probable action in the short to medium – term.

**As a conclusion, for the purposes of Demo4Grid market potential assessment (Deliverable 6.1.) it is advised that the Power to Gas market option will have to be handled as a secondary value stream to build a successful and profitable business case. Until, the above regulatory, technical and economic barriers are removed through modifications in the existing support policies (and mainly by introducing a**

green hydrogen feed-in tariff), this will not be a solid and profitable stand-alone business case for hydrogen producers through water electrolysis.

## 5.2. Power to Mobility

This is the second option / business case for hydrogen produced from water electrolysis, providing grid services / balancing. Using hydrogen in the mobility sector to contribute in greenhouse gases emissions reductions is an emerging market, the development of which requires additional refueling infrastructure. It is considered as a primary application, having good chances of profitability, but with higher payback periods of time as a stand-alone value stream. When combined with other methods of commercial exploitation of hydrogen (including power to gas), the payback time of the investment will significantly reduce.

The critical factor for the economic viability of the value stream of this application is the end-users acceptable final price of hydrogen. One basic assumption of this study was that the end-user will accept to pay a final price that is at least equal to the current cost of fossil fuels / km.

The end –user acceptance price is very important in order to calculate the price at which hydrogen will be provided by hydrogen producers through electrolysis to the owners of Hydrogen Refueling Stations (HRS), taking also into account the costs and profit margin of HRS operators. In this analysis, hydrogen is taken into account as tax-free in the short-term, as a policy to promote low and zero emission mobility.

In the following Table 4.2. the HRS operator acceptance prices per each mobility application are presented. This calculation has been based on specific reference boundary condition namely:

- Typical fleet consumption of hydrogen (daily, weekly, monthly and annually)
- Constraints that impact the operation of the electrolyzer and available storage tank
- Typical requirements of HRS
- Ranges for acceptable hydrogen prices

*The results of these calculations demonstrated that the acceptable prices of hydrogen for HRS operators ranges between 4 – 7 € / kg, depending on each mobility application. The cost margin for HRS operators ranges from 40% to 100%.*

**As a conclusion, for the purposes of Demo4Grid market potential assessment (Deliverable 6.1.) it is advised that the Power to Mobility market option should be handled as a primary value stream to build a successful and profitable business case. It is also advised that in order to maximize revenues and reduce significantly payback times, this business case should be (at least in the short-term) combined with one or**

more other applications (primary or secondary), such as power to gas, power to power or power to industry in order to come up with an attractive business case from the financial point of view.

**Table 4.2.** Acceptable hydrogen prices to end-users and HRS operators per mobile application (STUDY ON EARLY BUSINESS CASES FOR H<sub>2</sub> IN ENERGY STORAGE AND MORE BROADLY POWER TO H<sub>2</sub> APPLICATIONS, FINAL REPORT, June 2017, prepared by TRACTEBEL and Hincio for FCH JU).

Example of mobility applications	Forklift	Urban bus	Captive fleet of FCEV range-extenders
<b>Users</b>	B2B: Private operator (e.g. distribution centre)	B2B: Bus operator	B2B: Private operator (e.g. distribution or postal company, car-sharing schemes)
<b>Hydrogen supply</b>	Trailer delivery, semi-centralized or on-site production	On-site production	Trailer delivery, semi-centralized or on-site production
<b>Utilization rate</b>	2 to 3 shifts per day 330 days per year	250 km/day/bus 307 day per year	100 km/day/vehicle 330 days per year
<b>Typical fleet size (considered in this study)</b>	50 forklifts: 50 kg/day 200 forklifts: 200 kg/day	10 buses: 250 kg/day 20 buses: 500 kg/day	50 FCEV range-ext.: 50 kg/day 100 FCEV range-ext.: 100 kg/day
<b>H<sub>2</sub> consumption (average)</b>	33 tons per year (200 forklifts)	154 tons per year (200 buses)	16,5 tons per year (50 FCEV)
<b>Delivery pressure</b>	350 bar	350 bar	350 bar
<b>On-site production – Storage backup</b>	Dedicated 24h autonomy of storage (120 kg H <sub>2</sub> )	Dedicated 24h autonomy of storage (500 kg H <sub>2</sub> )	Dedicated 24h autonomy of storage (50 kg H <sub>2</sub> )
<b>Refuelling schedule</b>	Whole day depending of needs 2 to 3 refuelling per day (1 per shift) 330 days per year	1 refuelling per day at night 307 day per year	Whole day depending of needs 330 days per year
<b>Acceptable hydrogen fuel price to end-users (at the pump)</b>	11-12 €/kg	6-7 €/kg	9-10 €/kg
<b>Acceptable hydrogen fuel price delivered to station (selling price for the Power-to-Hydrogen system operator)</b>	6 – 7 €/kg H <sub>2</sub>	4 – 5 €/kg H <sub>2</sub> <sup>9</sup>	5 – 7 €/kg H <sub>2</sub> <sup>10</sup>

Table 40: Example of mobility business cases

<sup>9</sup> Calculated based on H<sub>2</sub> station CAPEX: 1,4 M€; OPEX: 4% of CAPEX; Power consumption: 3 kWh/kg; Electricity price: 100€/MWh; Lifetime: 10 years

<sup>10</sup> Calculated based on H<sub>2</sub> station CAPEX: 300 k€; OPEX: 4% of CAPEX; Power consumption: 3 kWh/kg; Electricity price: 100€/MWh; Lifetime: 10 years

### 5.3. Power to Industry

The third option / business case for hydrogen produced from water electrolysis, providing grid services / balancing is the one of selling hydrogen as a chemical in order to be used in industrial applications. The usage of hydrogen in industry can be divided into large and light applications depending on their hydrogen consumption volume. Large industry typically includes refineries, chemical plants and steel manufacture characterized by a very large quantity of hydrogen consumption (over 10,000 Nm<sup>3</sup>/hr). In these applications hydrogen is supplied either by Steam Methane Reforming (SMR) or by pipelines available in specific countries. On the other hand, light industrial applications are supplied by hydrogen either through trucks or small – scale SMR units. In industrial applications, hydrogen is used as a chemical required in the processes of the various categories of plants.

The Power to Industry business case is characterized as a primary value stream that has good chances for creating profitability, but when used as a stand-alone end-user results in higher payback periods of time. Therefore, a better economic viability



for this application can be achieved by combining this application of hydrogen produced from water electrolyzers with additional value streams in order to reduce payback times and increase profitability.

In general hydrogen required for large – scale industrial applications (especially in refineries) is produced through SMR at significantly lower costs compared to hydrogen produced from electrolysis. Unless, specific decarbonization policies are enforced in order to promote green hydrogen through subsidies, this business case will not be profitable for hydrogen producers using electrolyzers.

On the other hand, hydrogen required for light industrial applications could be a viable business case / value stream dependent on the specific conditions and the industrial sites locations. In more detail, in the context of the above mentioned study it has been concluded that in Denmark and France, there is a high potential for introducing hydrogen produced from electrolysis in light industry applications, due to high distances from any filling centre and the low competitive environment and high price of trucked in hydrogen. Similar favourable conditions for this value stream can also be found in other European areas.

**As a conclusion, for the purposes of Demo4Grid market potential assessment (Deliverable 6.1.) it is advised that the Power to Industry market option should be handled as a primary value stream to build a successful and profitable business case. It is evident that light industry applications come up with a higher profitability for hydrogen producers through water electrolysis. It is also advised that in order to maximize revenues and reduce significantly payback times this business case should be (at least in the short-term) combined with one or more other applications (primary or secondary), such as power to gas, power to power or power to gas in order to come up with an attractive business case from the financial point of view.**

## 5.4. Power to Power (Re-electrification of Hydrogen)

The fourth option / business case for hydrogen produced from water electrolysis is the one of producing energy in fuel cells driven by the previous stored hydrogen and selling it back to the electricity grid. Non-interconnected islands, where electricity is currently produced by burning diesel or heavy oil fuel are the best locations for hydrogen re-electrification, since the cost of energy produced in these systems is already high.

Power to Power business case should be combined with provision of grid services (combined grid balancing and frequency control) to have an additional income and make this application more economically attractive and profitable. Nevertheless, it should be noted that in almost all European countries there is not a regulatory provision for capacity payments for frequency containment.



From the financial point of view, the Power to Power option is stronger in small autonomous island systems that present an already high cost. It has been estimated that this business case becomes viable in island systems that present a power generation cost over 200 – 250 €/MWh, depending also on the availability of wind and solar potential. This option will highly contribute in the increase of renewable energy penetration in the weak electricity grids of islands and its decarbonization. The main competitor here, is batteries, but the Power to Power business case provides the advantage of seasonal energy storage.

**As a conclusion, for the purposes of Demo4Grid market potential assessment (Deliverable 6.1.) it is advised that the Power to Power market option should be considered in the short-term for small – size, non-interconnected islands with already high power generation costs. Power to produce hydrogen through the electrolyzer should be provided by renewables (excess electricity that cannot be absorbed by the grid). To achieve profitability this business case should be combined with the provision of grid services (grid balancing and frequency control) to maximize revenues and come up with an attractive investment.**

## 5.5. Grid Services Provision

The fifth option / business case for hydrogen produced from water electrolysis is the provision of grid services by the owner of the electrolyzer (hydrogen producer). This is a secondary value stream, since it cannot provide a profitable business case as a stand-alone application and should be considered as an additional income source, combined with a primary application. A water electrolyzer could potentially provide the following grid services to transmission and distribution operators:


- Balancing and management of congestion (transmission grid at national level)
- Frequency containment services for increased stability of the electricity network (at transmission grid and also includes enhanced frequency reserve service type)
- Distribution grid services: these services are not as mature as services at the transition level, the value for distribution grid should be assessed taking into account distribution grid CAPEX and OPEX, which can be avoided due to the flexibility associated with the operation of the electrolyzer (load shifting activation)

The revenues produced from the operation of an electrolyzer and its flexibility to provide grid services in each of the above described categories are depicted in the following paragraphs:

- **Balancing Services:** In cases where hydrogen production targets are clearly set for the electrolyzer over time periods, such as a week, while maintain a spare

capacity, it allows an electrolyzer to provide load shifting (meaning additional flexibility) for balancing services. Therefore, it could adopt its consumption to renewable energy variation. The analysis conducted in the context of this study, showed that the revenues of an electrolyzer providing balancing services vary according to the operation scenario. In the next Table 4.3., the expected revenues for a 1 MW electrolyzer providing balancing services for a number of case studies in different EU Member States and different activation costs are presented.

**Table 4.3.** Balancing services expected annual revenues for a 1 MW electrolyzer with 3 activation costs (STUDY ON EARLY BUSINESS CASES FOR H2 IN ENERGY STORAGE AND MORE BROADLY POWER TO H2 APPLICATIONS, FINAL REPORT, June 2017, prepared by TRACTEBEL and Hincio for FCH JU).



- **Load Frequency Control:** There is a great differentiation on the terms of regulation and remuneration related to ancillary services for Load-Frequency Control across EU member states, therefore the revenue expected from this application / business case of hydrogen produced through electrolysis, greatly differ
- **Distribution Grid Services:** In the context of the above mentioned study, specific simulations were realized, in order to calculate the profitability of this business case. The key results of this assessment indicated that the income linked to the flexibility provided by the electrolyzer are very low, since the electricity networks need to be reinforced to install the electrolyzer (which results in an additional capital cost), while this added value of its flexibility lies in postponing reinforcement investments. The calculations showed that the expected income from such an operation of the electrolyzer will be lower than 1 k€/MW/yr (annualized over the lifetime of the electrolyzer)

**As a conclusion, for the purposes of Demo4Grid market potential assessment (Deliverable 6.1.) it is advised that the Grid Services Provision market option should**

be handled as a secondary value stream to build a successful and profitable business cases. It is evident that provision of grid services (balancing services, load frequency control and distribution grid services) for hydrogen producers through water electrolysis should be combined with at least one other business case / application of hydrogen, such as power to mobility, power to industry, or power to gas. Such an approach would result in creating a more attractive and profitable business case for hydrogen producers.

## 5.6. Power to Heat

Power to Heat application of hydrogen is being sometimes overlooked due to the low overall efficiency of the process of producing hydrogen through electrolyzers using renewable electricity and then use hydrogen in H<sub>2</sub> burners in order to produce heat. This application has the disadvantage of needing additional infrastructure, mainly for the hydrogen burner, therefore it is usually less profitable compared to natural gas grid injection. Nevertheless, in specific cases (as in the demo site at MPREIS facilities realized in the context of Demo4Grid project), Power to Heat applications could turn into solid and profitable business cases. The main end-user of this application would be light industrial applications with high heating demand. The most important critical factors for the economic viability of this business case are: 1) cost of electricity, 2) distance from the end-user and 3) current cost of natural gas of the industrial users.

In cases of proximity of the industry to the hydrogen producer, low cost of electricity to produce hydrogen and high natural gas prices, the business case of Power to Heat gas good chances to become a viable and profitable investment. To increase income and profitability, it should be combined

**As a conclusion, for the purposes of Demo4Grid market potential assessment (Deliverable 6.1.) it is advised that the Power to Heat market option could become viable as a light industry application when the following conditions exist: 1) proximity of the industry to the hydrogen producer, 2) low cost of electricity to produce hydrogen, 3) high heating demand and 4) high natural gas prices. It is evident that Power to Heat applications to become profitable for hydrogen producers through water electrolysis should be combined with at least one other business case / application of hydrogen, such as power to mobility, or provision of grid services. Such an approach would result in creating a more attractive and profitable business case for hydrogen producers.**

## 5.7. List of at least 10 market opportunities at EU level

Following the analysis of business climate and current potential markets for the application of pressurized alkaline electrolyzers in providing grid balancing services the following market opportunities have been identified:

**1. Power to Gas application in Northern Germany: Although Power to Gas** applications are considered as a secondary value stream (due to the existing regulatory and legislative frameworks all over Europe), a solid application / business case of a pressurized alkaline electrolyzer for this scope can be set up in Northern Germany due to the high percentage of wind energy curtailments in the area. A significant market opportunity for the final concept of DEMO4GRID project can be created in this area of Europe, which will be facilitated by the fact that several demonstration projects in this field have been already realized in the last two decades, resulting in the acquisition of high – level experience for scaling it up.

**2. Power to Mobility application MPREIS (Austria):** MPREIS, a member of the consortium of DEMO4GRID project has already taken a strategic decision to replace a good part of its fossil-fuels driven vehicles with hydrogen ones. In addition, the company has already decided to install a pressurized alkaline electrolyzer to produce hydrogen that will be fed in a Hydrogen Refueling Station (HRS) to support its new hydrogen vehicle fleet. As analyzed above, the power to mobility business case is considered as a primary value stream for the DEMO4GRID targeted market segments and will most probably be a profitable business case as well. Moreover, such a large-scale introduction of hydrogen technologies in the transport sector will facilitate a wider use of hydrogen vehicles in commercial applications (heavy duty trucks) in Austria.

**3. Power to Mobility applications in Innsbruck Region (Austria):** The region of Innsbruck is one of the ones showing high penetration of hydrogen vehicles. Hydrogen refueling stations (HRS) are also located in this area. Therefore, it is sensible to identify a market opportunity for Pressurized Alkaline Electrolyzers in this location and this application, which will be higher in the next years, when the penetration of hydrogen vehicles will be higher.

**4. Power to Mobility application in AB Vasilopoulos logistic centre in Greece:** Logistic centres are considered one of the best markets for the commercial introduction of hydrogen technologies, including hydrogen production through Pressurized Alkaline Electrolyzers. The consortium of DEMO4GRID has already established contacts with one of the largest super market chains in Greece, namely AB Vasilopoulos, who are interested in creating the hydrogen production infrastructure required in order to substitute part of their battery electric forklift vehicles with hydrogen ones in their main logistics centre.

**5. Power to Industry application in Hellenic Petroleum SA (HELPE):** Hellenic Petroleum SA owns the biggest refinery in Greece and they are generally interested in investing in clean energy technologies. They are also leading the efforts for establishing the Greek Hydrogen Association, therefore they have a serious interest in investing in hydrogen energy technologies, including hydrogen production

through Pressurized Alkaline Electrolyzers. This could be one of the power to industry market opportunities for the end product of DEMO4GRID.

**6. Power to Power application in Milos island:** As explained in the above sections, Power to Power applications can become profitable only in small to medium scale non-interconnected islands, where hydrogen will be produced through electrolysis driven only by renewable energy (mainly wind energy), which cannot be absorbed by the weak island electricity grid. Power to Power applications should be supported by grid services provision (namely frequency and voltage control). Milos is a Greek island in the Southwestern Aegean Sea, with a peak electricity demand of 13-14 MW and ca. 5.000 inhabitants. In the island a small wind farm operates. The total yearly wind energy curtailments on the island exceed 20%, therefore Milos is ideal for such an application. Moreover, the Municipality of Milos has joined the FCH JU European Regions and Cities Initiative.

**7. Power to Power application in Kalymnos island:** Kalymnos is a Greek island in the Southeastern Aegean Sea (in Dodecanese complex) having similar characteristics with Milos. As a matter of fact, Kalymnos is a little bit bigger than Milos and has almost 9.000 inhabitants. The main difference is that Kalymnos is interconnected to other 8 islands, forming a non-interconnected complex, since these islands are not interconnected to the mainland. In the electricity network, several wind farms operate and the wind energy curtailments exceed 30%, therefore Kalymnos is an ideal business case for power to power applications, since energy storage is required. Moreover, Kalymnos has joined the FCH JU European Regions and Cities Initiative as well and has already developed its local hydrogen development plan, selecting specific business cases of hydrogen technologies, including local hydrogen production infrastructure through water electrolysis driven by renewable energy sources.

**8. Grid Balancing Services application in Crete island:** Crete is the biggest island of Greece, having a total population of over 680.000 inhabitants. A large number of wind farms have been installed and operate in the autonomous power system of the island, having reached the technical limit of penetration. Wind energy curtailments on this island are huge, surpassing 40%. As a consequence of this situation, there several problems related to the stability of the electricity grid, therefore the provision of grid balancing services (both frequency and voltage control) through the operation of Pressurized Alkaline Electrolyzers would be valuable for the power quality of the island of Crete.

**9. Grid Balancing Services application in Rhodes island:** Rhodes is the biggest island of Dodecanese, having a total population of over 115.000 inhabitants. Rhodes faces similar problems related to power quality and the operation of wind energy farms with Crete, but due to its high tourism development and the high difference in electricity requirements between summer and winter, the island

suffers from serious blackouts and stability problems. Therefore, provision of grid services through Pressurized Alkaline Electrolyzers would create a solid market opportunity for the end product of DEMO4GRID project.

**10. Power to Heat application in MPREIS Bakery industry:** MPREIS is one of the biggest bakery industries in Austria and it requires huge quantities of thermal power. Therefore, using hydrogen produced by Pressurized Alkaline Electrolyzers to feed suitable burners is a very good market opportunity for the final product of DEMO4GRID project. Moreover, to achieve the desired quality in baking of specific products of the company requires heat produced only by hydrogen, thus this is a solid business case.

## 6. CONCEPTS OF FINANCING AND SUPPORT

Due to the fact that hydrogen production for water electrolysis providing grid balancing and other similar services incorporates an additional (premium) cost, it is important to investigate available financing / funding and support policies to fill the gap of this extra cost at EU level. There are specific tools available at European level, which can be used in order either to finance, or even partly fund infrastructure of hydrogen production through water electrolysis for grid balancing and some of hydrogen applications described under Chapter 4. The most important funding / financing tools at EU level are the following:

- *European Regional and Development Fund (ERDF) and European Social Fund (ESF)*, with a total available budget of 562.6 billion Euro. These tools foresee a funding rate between 75% - 85% for the less developed regions, 60% for the transition regions and around 50% for the more developed regions. ERDF and ESF can be used to fund a variety of infrastructure for various applications, including hydrogen technologies
- *The Funding Programme Connecting Europe Facility (CEF) – Transport*, can be used to receive funds for the realization of hydrogen and fuel cell technologies (especially infrastructure) in the transport sector. The available total budget of the Programme, which is being managed by the European Investment Bank, is around 24 billion Euro. This Programme could be used in order to fund power to mobility applications and the development of hydrogen refueling stations (HRS). Only Projects of Common Interest (PCIs) are eligible for funding under the CEF tool
- *Cohesion Fund* aiming to strengthen the economic and social cohesion of Europe is also available in order to provide support in: 1) investments related to the improvement of environmental quality and sustainability, and 2) Trans-European Networks for Transport (TEN-T) with a total available of 3.8 billion Euro. Funding details depend on the national management authorities of each

Member State, while the maximum funding rate can reach up to 85% of the investments

- *Urban Innovation Actions – UIA Programme*, which is available to provide support in Urban European areas to test innovative solutions with a limited maturity level. The total budget of the Programme is 372 million Euro and a co-funding rate of at least 20% is required. It is available for Municipalities and Regions with a population of at least 50,000 inhabitants

Other funding and support tools are also available for hydrogen technologies in general, at national level at a significant number of Member States. National policies on the promotion of hydrogen technologies in general (including hydrogen production through water electrolysis for grid balancing) at the targeted countries (Austria, Spain and Greece) will be presented in the following paragraphs:

## 6.1. Austria

### The National Hydrogen Programme

At the 20th of Mar 2019 Austria launched the development of a hydrogen strategy to achieve the climate goals, which are defined in the #mission2030 - the Austrian climate and energy strategy. The strategy will be finished by the end of this year. The topic will be managed by the Federal Ministry for Sustainability and Tourism (BMNT) with the participation of the Federal Ministry of Transport, Infrastructure and Technology (BMVIT) in close collaboration with science, business and industry.

**Overall R&D-funding (Promotion of alternative propulsion systems and fuels) 60 M€ per year:**

- Mobility of the future: funding of cooperative R&D-projects
- FFG basis program: bottom-up product-optimization
- FFG-Headquarter program
- Research infrastructure (e.g.: Hydrogen Center Austria)
- Centers of competence (e.g. K2-Mobility, ViF)
- Climate & Energy Fund: R&D for energy carriers
- Climate & Energy Fund: Program “Zero Emission Mobility” preparing market introduction
- International networking (IPHE, IEA, H2020, Joint Undertaking “Fuel Cells & Hydrogen European technology platforms (ERTRAC BIOFUELS, ERA-NET Transport)

***R&D-Funding Programs “A3 & A3plus”: 50 Mio. Euro (2002-2011)***

4 calls for proposals (2002-2006):

152 proposals for evaluation → 79 projects selected (with FCH-Focus)

Total project volume: 39.6 Mio €

Funding: 20.5 Mio €

2 calls for Lighthouse Projects (2005&2006):



25 proposals for evaluation → 9 projects selected (with FCH-Focus)

Total project volume: 7.4 Mio €

Funding: 3.6 Mio €

5 calls for Lighthouse Projects (2007-2011):

139 proposals for evaluation → 76 projects selected (incl. 3 lighthouse projects with FCH-focus)


Total project volume: 44 Mio €

Funding: 25.8 Mio €

#### WIVA P&G:

In Austria the research association WIVA P&G (Wasserstoffinitiative Vorzeigeregion Austria Power and Gas -- [www.wiva.at](http://www.wiva.at)) was founded for the further development of the the Austrian energy system through an increased integration and implementation of **green hydrogen** and other (therefrom generated) hydrocarbons such as methane. Therefore WIVA P&G subsumes the experiences of more than 30 completed and ongoing projects and is going to implement 25 sub-projects within the energy model region. The founded research association WIVA P&G coordinates and implements the model region with the structure of an Austria-wide and therefore transregional, thematically focused and internationally visible cluster project. It has a multidisciplinary innovation structure, demonstrates and tests intelligent system solutions in practice, and provides applicable systems for users. There is no geographical restriction within Austria, so that WIVA P&G has a significant international visibility with its outstanding research projects.

System approach including hydrogen production, storage and use in transport, industry and stationary applications.



**R&D-Program “Mobility of the Future”. Funding for fuel cells and hydrogen: 17.1 M€**

Hydrogen Model Region “WIVA P&G”: Total Budget 125 Mio. € (Funding: 50 %)



1. **Green energy:** Production of green H<sub>2</sub> via electrolysis & storage, distribution, utilization of renewable energy
2. **Green industry:** Optimization of industrial processes, lowering emissions in the industrial sector and usage of hydrogen in different processes
3. **Green mobility:** New approaches for transport and logistics sector; lower CO<sub>2</sub> emissions (well-to-wheel) & local zero-emissions; higher efficiencies, lower costs for fuel cells; utilization of fuel cells in newly developed vehicles and applicants

## 6.2. Spain

In Spain, hydrogen technologies are also widely recognized and accepted as a tool with great potential to achieve the objectives of sustainability in the energy and transport sectors. In 2007, as part of the **Spanish Strategy for Climate Change and Clean Energy 2007 - 2013 – 2020**<sup>7</sup>, it was already indicated, as part of the action area in renewable energy, the generation of biohydrogen in the energy field, and the incentive of hydrogen technologies (such as fuel cells) to give solutions in the field of mobility using it as clean fuel generated from renewable energy. Thus, its importance in the different national strategies and action plans relating to renewable energy is being recognized due to its versatility and flexibility to be used in different applications.

Reference was also made on a preliminary basis to actions related to renewable energy and energy efficiency in the Renewable Energy Plan 2005 – 2010<sup>8</sup> and in the Energy Saving and Efficiency Strategy Action Plan 2008 - 2012 in Spain<sup>9</sup> respectively. Both documents have been updated and their second phase is being implemented, with hydrogen technologies still being widely described and characterised.

Recently, the National Renewable Energy Action Plan (NREAP) 2011 – 2020<sup>10</sup> is based on the mandates of the Directive 2009/28/EC of the European Parliament and of the Council of 23rd April, on the promotion of the use of energy from renewable sources which stipulated that each Member State should develop a National Action Plan in the field of Renewable energy, and updates to the Renewable Energy Plan 2005

- 2010. For the case of hydrogen, the role in the Plan is to support the renewable energy generation to store the surplus generated so that they can be used for different applications such as delivery to the gas network, sustainable mobility, uses in the chemical industry or re-electrification through fuel cells. There were therefore established goals for hydrogen generation through renewable energy that, despite some very low levels being established for the year 2020, make it clear that the clean hydrogen generated by renewable energy should begin to be considered in the short and medium term in Spain. In this scenario, the Secretary of State for Energy at the Ministry of Industry, Tourism and Trade, through the IDAE, decided to deepen in the NREAP 2011 - 2020. The objective of this analysis in 2011 was to consider the evolution of the world and Spanish economy and the analytical work of the Spanish energy strategy for the next 25 years. They recommended a participation in renewable energy of 20.8 % in 2020 in response to the Law No. 2/2011 of Sustainable Economy, which required the drafting of all the plans needed to meet the objectives of the Directive 2009/28/ EC. In this way, the Renewable Energy Plan (REP) 2011 – 2020<sup>11</sup> was launched following NREAP 2011 –

2020, which gave added depth to its objectives and also conducted an in-depth sectoral analysis. The REP 2011 - 2020, in its entirety, recognizes the potential of hydrogen technologies in the following areas:

- Clean biofuel generation as biodiesel.
- Clean biogas generation from biomass.
- Combustion engine propulsion.
- Gasification, fermentation and pyrolysis to get hydrogen from biomass.
- Electrochemical storage of hydrogen generated from electrolysis on a large scale to be used in the chemical industry, the gas network or in applications with fuel cells such as hydrogen-powered vehicles. This Plan recognizes hydrogen as the best alternative to store energy in the long term and large quantities of wind energy surplus, with regard to systems such as the adiabatic storage of energy in compressed air or electrochemical batteries.

In addition, in the sectoral analysis, hydrogen is explicitly mentioned in the different lines of R&D&I of REP 2011 - 2020 highlighting:

- Biogas sector: following the communication by the European Commission “European Strategic Energy Technology Plan (towards a low carbon future)” recognizes the potential of the conversion of biogas in hydrogen.
- Wind Sector: for the work areas which REP 2011 - 2020 recognizes (Work Area 3, applications), the ability is provided to search for the development of energy storage projects for its application in off-peak periods, through the use of systems for the production of hydrogen and fuel cells.
- Horizontal sector: accumulation systems of energy from the power grid. Hydrogen storage is described as promising for the future, for which large-scale demonstrations, efficiency increase and the seeking out, adaptation or building of systems suitable for storing are fundamental.

On the other hand, the **Energy Savings and Efficiency Action Plan (ESEP)**<sup>12</sup> has been updated for the period 2011 - 2020 and again for the period 2014 - 2020 following the adoption of the Directive 2012/72/EC on energy efficiency by the European Parliament and by the Council, which aims for a reduction of 20% in the energy consumption for all Member States.

In the fundamental version, developed for the period 2011 - 2020 and which will be subject of adaptation according to the mandates and directives to fulfil the 2020 objectives, hydrogen technologies applied to the transport sector are mentioned. Specifically, it recognises the importance of starting to renew conventional vehicle fleets with hydrogen and fuel cell propelled vehicles. In particular, in order to achieve this objective, financial aid is proposed for the acquisition of vehicles that use hydrogen as fuel by compensating the extra cost involved in their purchase.

Accordingly, the Ministry of Industry, Energy and Tourism (MINETUR), as an official body responsible for transposing the European Directive 2014/94 relating to the implementation of an infrastructure for alternative fuels, has included hydrogen as one of fuels to consider within

its Alternative Fuel Vehicle (AFV) Strategy. In this action, the commitment of MINETUR to these technologies is evident, since the transposition of the Directive to member countries with regard to hydrogen was optional and not compulsory.

	Fleet (No. Vehicles)		Infrastructure (No. public access supply / refuelling stations)	
	Current	Estimated 2020	Current	Minimum in 2020 according to Directive criterion
LPG	40.000	250.000	450	1.200
LNG	300	800	17 global	14 TEN-T
GNC	4.290	17.200	25 global	119 urban+17 in TEN-T
Electric Vehicle	10.000	150.000	Aprox. 1.000 in operation	1.190 urban
Hydrogen	Demonstration Projects	2.800	6	21

On the other hand, the report **Assessment of the Potential for the Development of Energy Technologies in Spain**, developed by the Alliance for Energy Research and Innovation (ALINNE), describes hydrogen and fuel cells technologies as one of those which will contribute to an extraordinary development of new energy technologies in the next ten years. In the end, as observed in the different existing plans previously described, it is clear that Spain recognizes the potential of hydrogen technologies to achieve the goals of the plans and strategies related to renewable energy, energy efficiency and sustainability. However, it is necessary to first achieve an increase in efficiency and a reduction of the cost of components and systems to achieve the competitiveness of hydrogen technologies with respect to those existing in the state of the art, for which support from national R&D&I plans is needed. It is undeniable that public authority, with honorable and notable exceptions, can do more for the deployment and development of these technologies. A possible reason for this may lie in the fact that knowledge of these technologies is not yet widespread in society.

In Spain, the **National R&D&I Plan** has been regularly updated since 1988. During the period 2005 - 2013, the percentage of financing allocated to projects related to hydrogen and fuel cells under the main calls for initiatives in collaboration (Singular Strategic Projects 2005 - 2011 and call INNPACTO 2010 – 2013), accounted for about 6.25% with respect to other thematic lines of the Plan as wind power and bioenergy.

Currently, the National Plan 2013 - 2016 recognises<sup>13</sup> a series of challenges including hydrogen technologies. In particular, the corresponding challenge to secure, efficient and clean energy is looking for a sustainable generation and an environmentally-friendly and socio-economically acceptable energy distribution. To do this, it promotes the transition towards an energy system that allows the reduction of fossil fuel dependence at a time when they are scarce and demand is growing, whilst at the same time their environmental impact is significant. Within this challenge, the fifth scientific-technical and business priority is hydrogen and fuel cells, including: (1) hydrogen production; (2) research and development of technologies for hydrogen and fuel cells; (3) hydrogen storage and distribution, and (4) portable and stationary hydrogen applications.

In Spain there are entities such as the Spanish Hydrogen Association (AeH2), the National Hydrogen Centre (CNH2), the Spanish Hydrogen and Fuel Cell Platform (PTEHPC) and the Spanish Fuel Cell Association (APPICE), which are very active in the promotion and development of projects related to hydrogen technologies.


In regard to the Spanish regions, practically all of them promote the use of technology and are active at national and European levels, especially Andalusia, Canary Islands, Catalonia, Autonomous Community of Madrid, Navarre, Galicia, the Basque Country, Valencia and Castilla La Mancha. It should be noted that in 2016, as an important national milestone, the World Congress of Hydrogen (World Hydrogen Energy Conference WHEC 2016), will be held in Zaragoza, Spain, from 13 thto 16<sup>th</sup> of June. The congress represents a great opportunity to position the Spanish leading figures in hydrogen and fuel cell technologies in the international arena. The event's key achievement and possible success will be the collaboration between FHa, supported by their members, and the main entities active in the national level, led by the AeH<sub>2</sub>.

### 6.3. Greece

There is no National Programme for the promotion of hydrogen technologies (including hydrogen production from water electrolysis for grid balancing among other applications) in Greece. Only demonstration R&D projects on this application may be funded up to 80% through the National R&I Programme of Greece (Research, Create, Innovate), in which certain topics of hydrogen technologies and fuel cells (including hydrogen production) are eligible.

## 7. MARKET OPPORTUNITIES ANALYSIS / SOLID BUSINESS CASES DEFINITION

As described in the first analysis of potential applications for an electrolyzer providing grid balancing services, it is evident that in order to come up with solid and profitable business cases and take advantage of early market opportunities, combinations between primary (Industry and Mobility) and secondary (Power to Gas and Gas injection, Power to Power (re-electrification in islands mainly) and Provision of Grid Services should be designed in order to maximize income and decrease payback time of the investment. In the following Figure 6.1., the basic scheme for business case definition is depicted.



**Figure 6.1.** Combinations of basic business cases (*Source: Study on early business cases for H2 in energy storage and more broadly power to H2 applications*)

As will be described in the next paragraphs the selection location is vital for a successful business case set-up, due to the fact that in areas with high grid constraints, there is access to low electricity cost to run the electrolyzer.

## 7.1. Existing Market Opportunities Analysis / Solid Business Cases Definition

To analyse the existing market opportunities and define complex business cases related to hydrogen production through water electrolysis to provide grid balancing services, comprising combinations of primary and secondary value streams, the first step is to understand the basic characteristics of each primary application as stand-alone:

- **Mobility applications:** Hydrogen supply for these applications can be both from production on-site or a delivery from a production unit located near – by, usually by truck delivery in a range of maximum 50 km. It should be taken into account that for different mobility applications, there is a significant variation in hydrogen prices
- **Light industrial applications:** There is a high variation in terms of hydrogen supply chain, requirements of the industrial customer and the specific location. Light industrial end – users for hydrogen could be oil and fat, glass manufacturing, metallurgy and electronics. Suitable end-users for hydrogen in light industrial applications are companies which a consumption that is high enough to justify on-site production
- **Large industrial applications:** refer to companies and processes which have high consumption of hydrogen, such as refineries, plants for ammonia production and steel mills. These industries can only be supplied through

large-scale on-site production, through pipelines distributing hydrogen gas. Currently, steam methane reforming (SMR) demonstrates significantly lower hydrogen production cost, compared to electrolysis driven by renewable electricity. Therefore, unless significant carbon taxes are introduced to SMR process (which is not expected by 2020), this is not a viable and profitable business case for hydrogen producers through water electrolysis in the short – term. Among the above mentioned industries, refineries could be a potential exception as business case, due to the fact that already today fuels are subject to specific targets on carbon intensity through Fuel Quality Directive and renewable share through the Renewable Energy Directive, which is under revision. Dependent on the targets under revision and its final values, refineries may become a new market for green hydrogen after 2020

A similar analysis took place for the secondary value streams for hydrogen through water electrolysis as stand-alone applications, before developing more complex business cases incorporating combinations between different primary and secondary applications. *A very important finding of the study, in relation to the supply of secondary value streams, is the fact that the electrolyzer can be de-optimized in terms of cost of electricity (meaning hydrogen production cost) compared to the initial hydrogen production plan, which was designed in order to supply the primary application.* The most important findings of the FCH JU on the viability of secondary value streams are the following:

- **Gas grid injection:** It allows to sell spare quantities of hydrogen not used by the primary application, in order to achieve additional income. The extra revenue is related to the supply of energy to the gas grid combined in parallel with the provision of grid services. In case the revenues coming from gas injection are high enough, an over-dimensioning of the electrolyzer in comparison with the size needed to supply the primary application can be well justified. The mode of operation of the electrolyzer in this case is that priority is given naturally in covering the demand of the primary application and when there is remaining capacity of hydrogen, it can operate with a profit as long as the marginal cost of operation is lower than the grid gas injection revenue. The operating hours are of course strongly dependent on the cost of electricity
- **Electricity Grid Services – Frequency:** The critical factor in deciding whether this application is economically profitable is the existing regulatory framework in each Member State or Region and its provisions on frequency containment. Therefore, depending on the type of reserve participation that is allowed by the regulatory framework (symmetric or asymmetric), the revenues from such an application are differently calculated:
  - Participation in a symmetric reserve demands the possibility to modify the electrolyzer's consumption up and down at any time. Therefore, especially for Alkaline Electrolyzers, which cannot exceed their nominal power, no revenues can be obtained, unless the electrolyzers are over-dimensioned for such an operation

- Participation in an asymmetric reserve requires the possibility to vary the electrolyzer's consumption either upwards, or downwards. Depending on the electrolyzer's state of operation (consuming electricity or not), the revenues can strongly vary, but they are not in any case zero values.

In general, alkaline electrolyzers do not present rapid response times (<30 sec) required from most electricity grid operators for providing frequency containment, therefore this secondary application is not considered highly profitable for the end-product of Demo4Grid project

- **Electricity Grid Services – Balancing:** If we compare the expected revenues for providing grid-balancing services as a stand-alone business with the supply of hydrogen in a primary application as well, a reduction in the overall potential is expected. Specific constraints exist when providing balancing services, while focusing first on hydrogen supply for a primary application:
  - The electrolyzer can be turned off to delay its load consumption in order to provide grid services, only if it was previously under operation (switched on)
  - The agreed hydrogen supply target should be achieved, independently whether it provides grid services or not. Therefore, the delayed consumption must be recovered within the day, at a higher cost of electricity
  - The grid service is provided only whenever includes benefits. The revenue associated with the load flexibility, called activation price, should at least cover the price difference linked with purchasing electricity at a higher cost

In general, from the calculations conducted in the context of the FCH JU study, it has been estimated that the revenues of the business case of providing grid balancing services are lower compared to the ones of gas grid injection and frequency containment. Therefore, this application should have much lower priority as a business case for the purposes of Demo4Grid project.

- **Electricity Grid Services – Balancing:** The analysis of this secondary application showed that the potential revenues associated with it were much lower, both in absolute values (as a stand-alone application) and in comparison with the other secondary applications. Therefore, this is not a solid and profitable business case to be taken into account in Demo4Grid project
- **Re-electrification of hydrogen in islands:** The profit to be obtained from this secondary application is generally based on the concept of buying electricity to produce hydrogen at a very low price and sell electricity from the re-electrification of hydrogen at a high price. As mentioned in Chapter 4, this application is not very profitable in most locations. More favourable conditions for this business case exist only in non-interconnected island systems, having already high cost of electricity production, using heavy oil or diesel fuel (total electricity production cost over 200 – 250 €/MWh). Local conditions related to



a combination of this application with at least another one result in a more profitable business case of this application

## 7.2. Identification of Critical Factors affecting Market Penetration

Having outlined the advantages and disadvantages of primary and secondary applications of hydrogen produced from water electrolysis in building solid and profitable business cases (both as stand – alone and combined applications), the second step is to identify the critical factors that should be taken into account when creating the business cases of Demo4Grid project. These factors strongly affect the economic viability and profitability of the business cases that will be selected as the first applications:

- **Cost of electricity:** From the analysis presented in the previous sections, it is evident that this is one of the most critical factors affecting directly hydrogen production cost and the overall profitability and payback times for a hydrogen production through water electrolysis investment. Low electricity cost can be found in areas and countries with high RES (especially wind energy) penetration and high excess renewable energy due to the fact that the available energy surpasses energy demand and cannot be absorbed by the electricity grid. This results in low electricity costs in order to increase load demand. Such favorable conditions in Europe can be found in Northern Europe, especially in Denmark, Germany and the UK, where there is a high penetration of wind farms and the energy produced is much higher compared to the consumption in nearby areas. The result of this situation is the presence of very low electricity (sometimes even negative) tariffs in specific periods of time
- **Location:** This is another critical factor affecting the profitability and economic viability of a hydrogen production from water electrolysis investment. The selection of the location, in which the electrolyzer will be installed is very important, since it can provide certain benefits and flexibility on the investment. The best locations to host such an investment are the following:
  - Areas with high RES (especially wind energy) penetration and high percentage of curtailments, resulting in high amounts of excess renewable energy – positive impact on hydrogen production cost
  - Countries with a regulatory framework allowing variable (even daily) electricity costs, depending on RES production and energy consumption – positive impact on hydrogen production cost and on selling electricity produced from hydrogen on high prices
  - Areas with extended natural gas grids and provisions on gas grid injection tariffs – solid business case (secondary application)



- Areas where light or large industries are located in a range of less than 50 km from the hydrogen production through electrolysis facility – primary application securing sales
- Countries and regions having already today a maturity on different mobility applications – primary application with a high perspective for increased revenues in the short - term

It is evident that the selection of locations combining the above mentioned characteristics makes the investment more profitable and economically viable, since different applications (primary and secondary) can be combined in order to maximize revenues

- **Dimensioning of the electrolyzer:** This is a critical design parameter directly affecting the financial viability of the hydrogen production investment. When dimensioning the electrolyzer the following should be taken into account:
  - Current and future primary and secondary applications
  - Regulatory framework, especially on gas grid injection and on provision of grid services (mainly frequency containment and grid balancing)
- **Regulatory framework:** This is one of the most important factors that should be taken into account when designing the development of the hydrogen production investment as was also explained in the previous critical factors. Regulatory frameworks having provisions for: 1) hydrogen injection tariffs in the natural gas network, 2) variable costs of electricity (mainly the ability to buy electricity from renewables at very low prices to produce hydrogen through the electrolyzer, thus minimizing hydrogen production cost), 3) existing carbon taxes on hydrogen production through steam methane reforming and 4) specific support policies for financing and funding of hydrogen and fuel cell technologies create favorable economic and financial conditions for a successful and profitable investment on hydrogen production
- **Hydrogen prices:** Another critical factor that is often being overlooked when scheduling and designing an investment on hydrogen production through water electrolysis (driven by renewable electricity) is the current prices of hydrogen procurement in the country or region. It is obvious that such an investment installed in countries or regions having already today a high cost of hydrogen procurement creates favorable conditions for its viability and profitability

It can be easily understood that when combining several positive aspects on the above mentioned critical factors, the favorable conditions for the hydrogen production investment are multiplied.

### 7.3. Bankability Analysis of Business Cases

Following the previous analysis on creation of market opportunities and the identification of critical success factors for an investment on hydrogen production through water electrolysis (using excess and low-cost RES electricity), the bankability

analysis presented in this chapter results in a complete assessment on business models for the purposes of Demo4Grid project.

As described earlier in this Deliverable, there are already today bankable business cases for Power to Hydrogen, by combining hydrogen sales (either in the industry or mobility applications) and provision of flexibility services. The latter is a lower income compared to H<sub>2</sub> sales, but is complimentary to it and contributes in increasing the profitability of the investment. The European Study on Power to Hydrogen by FCH JU revealed that this is a market of a total electrolyzers' installed capacity in the order of 3.1 GW, representing a total value of 4.7 billion Euro.

In any case, low cost electricity, supported by partial exemption from grid fees, taxes and levies is needed in order such an investment to become profitable and economically viable in the short term. Such an approach is examined in the regulatory framework modification of many countries, since Power to Hydrogen investments are a profitable and easy method to achieve high renewable energy penetration, by significantly reducing curtailments (especially in wind energy) in the European energy system and meet decarbonization targets.

The strongest synergies identified between different Power to Hydrogen Applications in building solid, profitable and bankable business cases are the ones of selling hydrogen to mobility application, gas grid injection and grid services. When designing a bankable investment on Power to Hydrogen, the following should be taken into account, when deciding the potential end-users to be selected:

- Combining Power to Hydrogen for mobility and / or light and large industrial applications with gas grid injection is more cost effective than a stand-alone injection of hydrogen for greening the natural gas. The stand-alone gas grid injection application will require a minimum feed – in tariff of 100 €/MWh in order to be economically viable. When this application is combined with hydrogen sales in the mobility or industrial sector, the above mentioned tariff needed for the investment in order to become viable can be reduced up to 20%
- The combination of hydrogen injection into the natural gas grid and hydrogen sales in the mobility and/or industrial sector (as primary applications) is a perfect business approach in order to de-risk the investment through the valley of death of mobility and industry

The bankability of the Power to Hydrogen investment can be highly facilitated from a consistent and stable regulatory framework comprising favorable provisions (grid fees, taxes and levies partial exemption etc.) to promote hydrogen technologies.

The revision of the Renewable Energy Directive (RED) and the upcoming Renewable Energy Directive II (RED2 – Winter Package), will be a unique opportunity to create market opportunities also in large – scale industry and more specifically in refineries. Such a modification in the regulatory framework and energy policy in

general, will be highly beneficial for Power to Hydrogen using renewable electricity as it will become economically competitive with SMR hydrogen and will also have rapid positive effects in other applications, including mobility.

## 8. IDENTIFICATION OF RISKS AND DE-RISKING AT BUSINESS LEVEL / RECOMMENDATIONS TO DECREASE RISKS

Power to Hydrogen business cases include a significant investment risk for hydrogen producers through water electrolysis for a number of reasons. The basic problem that creates investment risks, is that currently this is an immature market, which has not been regulated and well organized. Contractual arrangement is the best tool to identify the risks of the investment and create conditions towards the bankability of these projects. In this Chapter an analysis on the potential risks and de-risking guidelines will be presented along with a list of recommendations for modifications to the existing regulatory frameworks in order to increase bankability and profitability of Power to Hydrogen investments.

### 8.1. De-Risking of Power to Hydrogen Applications

As already mentioned, solid contractual arrangements are considered to be the most important tool in order to de-risk Power to Hydrogen investments. Taking into account the complexity of all business cases in the field and the fact that the electrolyzer operator and owner should interact with different market players in different fields of activity, the following guidelines in the contractual agreements should be followed in order to reduce the investment risk:

- With respect to the model of electricity purchases for the operation of the electrolyzer, the following provisions should be taken: 1) Electricity must be purchased directly from the electricity market at the wholesale electricity price. In case of time periods when instantaneous local curtailments occur, 2) Electricity should be directly purchased from the curtailed renewable power plant (in terms of location into the electricity grid, meaning a connection at the same transmission level substation as the generator), leading to a lower price than the wholesale electricity price. The counterparty of this contract agreement depends on national regulatory frameworks. This is a contractual agreement that significantly reduces the risk on the electricity costs paid to run the electrolyzer and has already been recognized as a critical factor for the viability of such an investment
- With respect to grid fees, which are charged by the electricity grid operator for a connection to the network, it is very important to have favorable prices in

order to de-risk the investment. These prices are determined by the national regulatory frameworks, therefore a Power to Hydrogen business will be economically viable in Member States with low grid fee prices for such an operation

- Another risk for the Power to Hydrogen investments is related to taxes and levies, which strongly vary between different Member States. A stable and consistent regulatory framework in terms of taxes and levies strongly reduces the risks of the investment, therefore countries having already today favorable conditions on this issue should be selected in order to de-risk the investment
- Regarding grid services provision (especially frequency containment), it should be noted that these are provided to the TSO and the remuneration for either availability or for effective use on request strongly vary depending on the national regulatory frameworks of different Member States. To minimize this risk, Power to Hydrogen Investors should locate their facilities in areas presenting favorable and stable conditions on this parameter
- On the application of grid gas injection, to minimize the risk of the Power to Hydrogen investment, the operators of electrolyzers should seek for a contract agreement, in which hydrogen is sold to the gas grid operator as green gas through a promotional feed – in tariff. Therefore, also in this case the selection of areas with favorable tariffs for green gases will significantly contribute to de-risking of the investments

The most important method that should be used in order to de-risk Power to Hydrogen investments and increase their bankability is to design the business cases taking into account a long-term perspective on costs and revenues.

Regarding costs of hydrogen production (strongly related to the electricity costs), there is a strong difficulty to design the investment with a safe long – term perspective. The electrolyzer owners and operators are basically an electricity consumer and as such they can, in the long – term, face variable fees, taxes and levies, which are not related to electricity supply cost and may play an important role in the economic viability and profitability of the overall investment. In several countries, exemptions on fees, taxes and levies exist, aiming to promote this technology, but the most important factor on the regulatory framework is the duration of such exemptions, and its stability, in order the investor to have a guarantee that these favorable conditions will not be removed suddenly.

Regulatory frameworks providing higher certainty are the ones which offer similar exemptions for a period of at least 10 years, therefore covering the best part of the lifetime of the investment. This is currently the case for grid fee exemptions that exists in Germany already today.

With respect of the revenue costs of the business case of hydrogen production through water electrolysis driven by excess renewable electricity, an important aspect of the business case development is securing contracts for the supplied hydrogen to

different end – users of primary applications. The risk associated to this investment (mainly regarding the volume of hydrogen to be sold in different clients) can be further reduced in Member States or regions offering feed – in tariffs for hydrogen injection to the natural gas grid.

## 8.2. Recommendations on Modifications to Regulatory Frameworks to decrease Risks

As described in previous sections the financial viability and profitability of Power to Hydrogen business cases, is strongly affected by the existing regulatory framework in each European country or region. The scope of this paragraph is to provide recommendations for potential modifications on the existing regulatory frameworks in order to promote hydrogen production through water electrolysis, driven by renewable electricity so as to come up with solid and profitable business cases in the short and medium – term. The most critical recommendations for changes on the regulatory frameworks, affecting positively the economic viability and profitability of Power to Hydrogen business cases are the following:

- There should be provisions in the regulatory frameworks in order to avoid the inflation of electricity prices with costs that are not related to electricity supply. As mentioned earlier, a beneficial for the investment regulatory modification would be to include partial exemptions from paying grid fees, taxes or levies. Such an approach can be justified for the Member States on the grounds that electrolyzers operate in a mode that is highly beneficial for the European energy system. This provision is very important on the viability and profitability of the investment, since in several European countries, taxes and levies constitute around 50% of the electricity bill. Therefore, such favorable provisions on the regulatory framework will result in a significant reduction of the hydrogen production cost
- The existence of a clear regulatory framework on how curtailed RES electricity is accessed, is essential in order to facilitate the uptake of bilateral contracts between RES producers (especially wind energy producers) and potential end – users. Such provision on the regulatory framework would result in avoiding, or at least significantly reducing RES power curtailments
- Another important guideline / recommendation for modifications at the regulatory framework positively affecting the profitability of Hydrogen to Power business cases is the development of EU framework guidelines in order to provide an environment allowing access to frequency control grid service, focusing especially on asymmetric procurement. Such a provision in the regulatory frameworks would also result in increasing the income of these investments

- Regulatory frameworks should be modified in order to include provisions that allow specific feed – in tariffs for the injection of zero – carbon gas into the natural gas grid. These provisions could refer to either bio – methane or green hydrogen. Feed – in tariffs are already available for bio-methane injection to the natural gas grid, therefore it is recommended to modify the existing regulatory frameworks in order to include feed – in tariffs for green hydrogen injection as well
- An allowance in the regulatory frameworks for inclusion of green hydrogen in the carbon intensity calculation of conventional fuels in the forthcoming revision of the Fuel Quality Directive (FQD) and the expected revision of the Renewable Energy Directive (RED II) will also be beneficial for the economic viability and the profitability of Hydrogen to Power investments, introducing hydrogen produced from renewable electricity through water electrolysis into the refineries (large – scale industrial applications) market as well

## 9. CURRENT AND FUTURE COST PERSPECTIVES

The capital cost of the alkaline electrolyzers is an important factor, affecting directly the economic viability and the profitability of Power to Hydrogen applications and value streams (primary and secondary). Future cost reductions of the current prices of alkaline electrolyzers (including the PAE developed in the context of Demo4Grid) project will be needed in order to decrease the hydrogen production and result in solid business cases. In this Chapter, current costs for alkaline electrolyzers are presented and an analysis of future cost perspectives is demonstrated.

### 9.1. Current Costs of Alkaline Electrolyzers

In previous years the capital cost of electrolyzers was extremely high and acted as a barrier for the development of solid and profitable Power to Hydrogen applications. In more detail, back in 2014 the capital cost of alkaline electrolyzer systems ranged between 1,000 and 1,500 €/kW plus installation. One of the basic objectives of Demo4Grid project was to achieve lower cost and CAPEX, in order comply with the Key Performance Indicators (KPIs) of the Multi Annual Work Plan (MAWP) presented by FCH JU.

The basic objective met by Demo4Grid was to demonstrate manufacturing costs for the 4MW single-stack PAE not higher than 725 kEUR/MW. These costs include power electronics, system control, gas drying (condenser/demister -> H<sub>2</sub> purity of

99,6%) and commissioning but exclude grid connection, hydrogen storage, additional external purification and compression. Regarding the addition of external compressor, which represents a remarkable extra cost, it should be mentioned that for the specific applications in the context of Demo4Grid project, the 4MW PAE (generating H<sub>2</sub> @ at least 33 bars @ full load), did not require the installation of any additional mechanical or other type of compressor (sometimes this type of ancillary equipment is necessary to make possible or facilitate storage operations in case of lower pressure electrolyzers) and therefore enables significant cost savings at the demo site.

Creating a link between manufacturing costs of the 4 MW Pressurized Alkaline Electrolyzer (PAE) and its high efficiency, PAE manufactured in the context of Demo4Grid project showed that it complied with all 2020 CAPEX KPIs shown in the following Table 8.1.

**Table 8.1.** Efficiency KPI 1 and Capex KPI 2 (MAWP, FCH JU)

			2017	2020	2023
MAWP KPIs	Efficiency KPI 1	(kWh/kg)	55	52	50
	Capex KPI 2	(M€/T/d))	3,7	2,0	1,5
		(€/kW) <sup>(a)</sup>	1617	925	721

<sup>(a)</sup> Calculated on the basis of efficiency (kWh/kgH<sub>2</sub>) and Capex (M€/T/d)) assuming 24 hours operation @ nominal power

## 9.2. Future Cost Perspectives of Alkaline Electrolyzers

The capital cost objective of Demo4Grid project for alkaline electrolyzers complies with the cost targets for 2020, identified by the FCH-JU study “Water Electrolysis in the European Union” (<http://www.fch.europa.eu/node/783>) according to which alkaline electrolyzer systems cost expectations for 2020 should be in the range 370-900 €/kW, central case 630 €/kW, as shown in Table 8.2.

**Table 8.2.** System costs KPIs for Alkaline Electrolyzers (“Water Electrolysis in EU” FCH JU Study)



System cost <sup>(1)</sup>			Today	2015	2020	2025	2030
EUR/kW	Alkaline	Central	<b>1,100</b>	<b>930</b>	<b>630</b>	<b>610</b>	<b>580</b>
		Range	1,000 - 1,200	760 - 1,100	370 - 900	370 - 850	370 - 800
	PEM	Central	<b>2,090</b>	<b>1,570</b>	<b>1,000</b>	<b>870</b>	<b>760</b>
		Range	1,860 - 2,320	1,200 - 1,940	700 - 1,300	480 - 1,270	250 - 1,270

<sup>(1)</sup> incl. power supply, system control, gas drying (purity above 99.4%). Excl. grid connection, external compression, external purification and hydrogen storage

The results of the above mentioned study showed that in order to achieve these targets, several pathways will need to be pursued in parallel

- Higher-volume/mass production
- Supply chain development
- Technology innovation

Volume production and supply chain development will occur in parallel with increased deployment of electrolyzer (namely PAE) systems. These two parameters however, always according to the FCH JU study “Water Electrolysis in the European Union”, are broadly not affected by technology development, except for technology innovations that can enable the use (if possible) of standardized low cost components already in mass manufacture.

This is valid already today for alkaline water electrolysis technology, frequently regarded as more well-established than others (e.g. PEM), and for which technology innovation is seen as a comparatively less important contributor to anticipated cost reductions.

It is important to note that today alkaline electrolyzers (even if regarded as a fully “mature” technology) are built in small volumes for niche markets, therefore when going to mass production, significant cost reductions will be achieved.

Sales and hence production volumes are low. The choice of suppliers for specific system/Balance of Plant (BoP) components is also limited and that may contribute to increase manufacturing costs.

According to the same FCH JU study “Water Electrolysis in the European Union”, it is expected that much of the cost reduction potential will come from “an improved supply chain, and through increased production volumes for which more cost-efficient production techniques can be used”. The study also states that “the achievement of the expected reductions in cost is therefore directly dependent on the level of deployment in a given time period”.

In conclusion, Demo4Grid has already proved that, despite of the current low level of deployment and the need to deliver the multi megawatt PAE well before 2020, manufacturing costs will be contained within limits fully compatible with MAWP 2020



Capex KPI and in line with the expected costs range defined in the FCH JU study “Water Electrolysis in the European Union”.

## 10. CONCLUSIONS

In the context of Deliverable 6.1. of Demo4Grid project, a detailed market potential assessment on different business cases of hydrogen production through alkaline electrolyzers for a variety of primary and secondary applications was presented. The main scope of this deliverable was to identify benefits on hydrogen applications in grid balancing in combination with other value streams. The analysis conducted in this Deliverable produced the following conclusions:

- Hydrogen production through water electrolysis can provide a high flexibility in the European energy system, due to the high number of potential applications in different fields. It can also significantly contribute in achieving a high increase in the penetration of RES and meeting decarbonization goals of the European Union. Moreover, hydrogen is an ideal energy storage method, due to its characteristics (large-scale, long-term, ability to be injected to the natural gas grid), contributing also in the transmission of energy produced in area with high renewable energy capacity to the consumption centres
- A number of European and National policies to promote Renewable Energy Sources in the EU energy system. The most important policy is the Clean Energy for all European Energy Package, part of which will be the revised Renewable Directive II (RED 2) that will play important role in opening new markets for hydrogen produced through electrolyzers. Certain EU policies have been planned with respect to the promotion of energy storage in the European energy system as well (initiatives and tools such as SET plan, Fuel Cells and Hydrogen Joint Undertaking – FCH JU, EU Battery Alliance, HORIZON 2020). The most important policy underway in order to promote energy storage in Europe will be the Energy Storage Directive, which is being prepared, having completed already the discussion with stakeholders
- The analysis of business climate and identification of potential markets for Pressurized Alkaline Electrolyzers (PAE) showed that there is a high potential even in the short-term at European level. Power to Hydrogen (to contribute to Grid Balancing as well) is a bankable business case already today. According to the European “Study on early business cases for H<sub>2</sub> in energy storage and more broadly power to H<sub>2</sub> applications”, it is estimated that the electrolyzer capacity to be installed by 2025 in Europe is in the order of 2.8 GW. This estimation is based on sound economics and represents a total market value of € 4.2 bn. The short-term estimations for profitable business cases in this market are respectively 1.4 GW and € 2.6 bn

- With respect to the different Power to Hydrogen business cases the basic conclusion of the analysis realized in the context of this Deliverable was that in order to achieve profitability, different value streams (primary and secondary) should be combined. The more detailed conclusions per business case are the following:
  - **Power to Gas:** This market option will have to be handled as a secondary value stream to build a successful and profitable business case. Until, the regulatory, technical and economic barriers are removed through modifications in the existing support policies (and mainly by introducing a green hydrogen injection feed-in tariff), this will not be a solid and profitable stand-alone business case for hydrogen producers through water electrolysis
  - **Power to Mobility:** This market option should be handled as a primary value stream to build a successful and profitable business case. It is also advised that in order to maximize revenues and reduce significantly payback times, this business case should be (at least in the short-term) combined with one or more other applications (primary or secondary), such as power to gas, power to power or power to industry in order to come up with an attractive business case from the financial point of view
  - **Power to Industry:** The analysis conducted in this Deliverable showed that this market option should be handled as a primary value stream to build a successful and profitable business case. It is evident that light industry applications come up with a higher profitability for hydrogen producers through water electrolysis. It is also advised that in order to maximize revenues and reduce significantly payback times this business case should be (at least in the short-term) combined with one or more other applications (primary or secondary), such as power to gas, power to power or power to gas in order to come up with an attractive business case from the financial point of view
  - **Power to Power:** The assessment for this market option, showed that it should be only considered in the short-term for small – size, non-interconnected islands with already high power generation costs, with the latter being the most important decision factor. Power to produce hydrogen through the electrolyzer should be provided by renewables (excess electricity that cannot be absorbed by the grid). To achieve profitability this business case should be combined with the provision of grid services (grid balancing and frequency control) to maximize revenues and come up with an attractive investment.
  - **Grid Services Provision:** This market option should be handled as a secondary value stream to build successful and profitable business cases. It is evident that the provision of grid services (balancing services, load frequency control and distribution grid services) for hydrogen producers through water electrolysis should be combined

with at least one other business case / application of hydrogen, such as power to mobility, power to industry, or power to gas. Such an approach would result in creating a more attractive and profitable business case for hydrogen producers

- **Power to Heat:** This market option could become viable as a light industry application when the following conditions exist: 1) proximity of the industry to the hydrogen producer, 2) low cost of electricity to produce hydrogen, 3) high heating demand of the industry and 4) high natural gas prices. It is evident that Power to Heat applications to become profitable for hydrogen producers through water electrolysis should be combined with at least one other business case / application of hydrogen, such as power to mobility, or provision of grid services. Such an approach would result in creating a more attractive and profitable business case for hydrogen producers.
- In the context of Deliverable 6.1., the critical factors affecting economic viability and profitability of Power to Hydrogen business cases was performed; the most important factors to build a solid business case scenario were:
  - *Cost of Electricity*
  - *Location of the investment*
  - *Dimensioning of the electrolyzer*
  - *Regulatory Framework*
  - *Hydrogen Prices*
- The identification of critical factors provided feedback in the identification of risks related to hydrogen production through water electrolysis business cases. The de-risking procedure was developed in the context of this Deliverable, followed by recommendations on potential modifications on the regulatory and legislative framework at European and National level, in order to minimize risks and contribute in the development of solid Power to Hydrogen business cases in the short – term
- Finally, in this Deliverable, current costs of alkaline electrolyzers were recorded and an analysis of the future cost perspectives (CAPEX, hydrogen production and manufacturing costs) was performed

## REFERENCES

1. “Study on early business cases for H2 in energy storage and more broadly power to H2 applications”, Final Report, 2017, prepared by TRACTEBEL and Hinić on behalf of FCH JU
2. “Development of Water Electrolysis in the European Union” Final Report, 2014, prepared for Fuel cells and hydrogen Joint undertaking by E4tech and Element Energy
3. [hybalance.eu](http://hybalance.eu)

4. COMMISSION STAFF WORKING DOCUMENT “Energy storage – the role of electricity”, July 2017, EC (SWD 61 Final)
5. COMMUNICATION FROM THE COMMISSION TO THE EUROPEAN PARLIAMENT, THE EUROPEAN COUNCIL, THE COUNCIL, THE EUROPEAN ECONOMIC AND SOCIAL COMMITTEE, THE COMMITTEE OF THE REGIONS AND THE EUROPEAN INVESTMENT BANK, “A Clean Planet for all: A European strategic long-term vision for a prosperous, modern, competitive and climate neutral economy”, EC COM (2018) 773 final
6. “Balancing the Grid with hydrogen technologies”, Bernard Frois, CEA and International Partnership for Hydrogen and Fuel Cells in the Economy Chairman (2017)
7. “Energy Storage in EU energy policies”, Tudor Constantinescu, PhD Principal Adviser, European Commission – Energy, Brussels, Eurelectric, 7 December 2017
8. “Reflections on Energy Storage”, Yolanda Garcia Mezquita, ENER-B4, Florence Forum, May 2018
9. “Natural Gas Storage in Salt Caverns – Present Status, Developments and Future Trends in Europe”, Gillhaus, A. (2007)
10. Eurogas (2015): Statistical Report
11. “Hydrogen Roadmap Europe: A SUSTAINABLE PATHWAY FOR THE EUROPEAN ENERGY TRANSITION”, FCH JU and European Commission, January 2019
12. National Renewable Energy Action Plan, Austria
13. National Renewable Energy Action Plan, Spain
14. National Renewable Energy Action Plan, Greece
15. DIRECTIVE 2009/28/EC OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 23 April 2009 on the “promotion of the use of energy from renewable sources and amending and subsequently repealing Directives 2001/77/EC and 2003/30/EC”
16. “THE REVISED RENEWABLE ENERGY DIRECTIVE – FACTSHEET” EC, 2018 EC “2050 Long – Term Energy Strategy”, <https://ec.europa.eu/energy/en/topics/energy-strategy-and-energy-union/2050-long-term-strategy>